



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Project Description

Center Street

For:

Michael Coghlan

Horseheads Central School District

507 Fletcher Street

Horseheads, NY 14845

Customer Relationship Specialist

Renee Lantz

Tuesday, August 26, 2025

Please find enclosed the analytical results for the samples you submitted to Microbac Laboratories. Review and compilation of your report was completed by Microbac Laboratories, Inc., Sayre Division. If you have any questions, comments, or require further assistance regarding this report, please contact your service representative listed above.

I certify that all test results meet all of the requirements of the accrediting authority listed within this report. Analytical results are reported on a 'as received' basis unless specified otherwise. Analytical results for solids with units ending in (dry) are reported on a dry weight basis. A statement of uncertainty for each analysis is available upon request. This laboratory report shall not be reproduced, except in full, without the written approval of Microbac Laboratories. The reported results are related only to the samples analyzed as received.

Microbac Laboratories, Inc.

2310 Elmira Street | Sayre, PA 18840 | 570-888-0169 p | www.microbac.com



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Horseheads Central School District

Michael Coghlan
507 Fletcher Street
Horseheads, NY 14845

Project Name: Center Street

Project / PO Number: 25-02362
Received: 06/30/2025
Reported: 08/26/2025

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
KIT 1	S5F0629-01	Drinking Water	Grab		06/25/25 04:30	06/30/25 18:25
KIT 2	S5F0629-02	Drinking Water	Grab		06/25/25 04:31	06/30/25 18:25
KIT 3	S5F0629-03	Drinking Water	Grab		06/25/25 04:32	06/30/25 18:25
STE 1	S5F0629-04	Drinking Water	Grab		06/25/25 04:33	06/30/25 18:25
BOT 1	S5F0629-05	Drinking Water	Grab		06/25/25 04:34	06/30/25 18:25
F-1	S5F0629-06	Drinking Water	Grab		06/25/25 04:35	06/30/25 18:25
F-2	S5F0629-07	Drinking Water	Grab		06/25/25 04:36	06/30/25 18:25
104A	S5F0629-08	Drinking Water	Grab		06/25/25 04:37	06/30/25 18:25
104B	S5F0629-09	Drinking Water	Grab		06/25/25 04:38	06/30/25 18:25
107A	S5F0629-10	Drinking Water	Grab		06/25/25 04:39	06/30/25 18:25
107B	S5F0629-11	Drinking Water	Grab		06/25/25 04:40	06/30/25 18:25
102A	S5F0629-12	Drinking Water	Grab		06/25/25 04:41	06/30/25 18:25
102B	S5F0629-13	Drinking Water	Grab		06/25/25 04:42	06/30/25 18:25
105A	S5F0629-14	Drinking Water	Grab		06/25/25 04:43	06/30/25 18:25
105B	S5F0629-15	Drinking Water	Grab		06/25/25 04:44	06/30/25 18:25
103A	S5F0629-16	Drinking Water	Grab		06/25/25 04:45	06/30/25 18:25
103B	S5F0629-17	Drinking Water	Grab		06/25/25 04:46	06/30/25 18:25
NUR	S5F0629-18	Drinking Water	Grab		06/25/25 04:47	06/30/25 18:25
101A	S5F0629-19	Drinking Water	Grab		06/25/25 04:48	06/30/25 18:25
101B	S5F0629-20	Drinking Water	Grab		06/25/25 04:49	06/30/25 18:25
F-3	S5F0629-21	Drinking Water	Grab		06/25/25 04:50	06/30/25 18:25
BOT-2	S5F0629-22	Drinking Water	Grab		06/25/25 04:51	06/30/25 18:25
F-4	S5F0629-23	Drinking Water	Grab		06/25/25 04:52	06/30/25 18:25
FAC1	S5F0629-24	Drinking Water	Grab		06/25/25 04:53	06/30/25 18:25
113A	S5F0629-25	Drinking Water	Grab		06/25/25 04:54	06/30/25 18:25
113B	S5F0629-26	Drinking Water	Grab		06/25/25 04:55	06/30/25 18:25
115A	S5F0629-27	Drinking Water	Grab		06/25/25 04:56	06/30/25 18:25
115B	S5F0629-28	Drinking Water	Grab		06/25/25 04:57	06/30/25 18:25
110A	S5F0629-29	Drinking Water	Grab		06/25/25 04:58	06/30/25 18:25
110B	S5F0629-30	Drinking Water	Grab		06/25/25 04:59	06/30/25 18:25
117A	S5F0629-31	Drinking Water	Grab		06/25/25 05:00	06/30/25 18:25
117B	S5F0629-32	Drinking Water	Grab		06/25/25 05:01	06/30/25 18:25
112A	S5F0629-33	Drinking Water	Grab		06/25/25 05:02	06/30/25 18:25
112B	S5F0629-34	Drinking Water	Grab		06/25/25 05:03	06/30/25 18:25
114A	S5F0629-35	Drinking Water	Grab		06/25/25 05:04	06/30/25 18:25
114B	S5F0629-36	Drinking Water	Grab		06/25/25 05:05	06/30/25 18:25

BOT-3	S5F0629-37	Drinking Water	Grab	06/25/25 05:06	06/30/25 18:25
F-5	S5F0629-38	Drinking Water	Grab	06/25/25 05:07	06/30/25 18:25
F-6	S5F0629-39	Drinking Water	Grab	06/25/25 05:08	06/30/25 18:25
121A	S5F0629-40	Drinking Water	Grab	06/25/25 05:09	06/30/25 18:25
118A	S5F0629-41	Drinking Water	Grab	06/25/25 05:10	06/30/25 18:25
123A	S5F0629-42	Drinking Water	Grab	06/25/25 05:11	06/30/25 18:25
120A	S5F0629-43	Drinking Water	Grab	06/25/25 05:12	06/30/25 18:25
125A	S5F0629-44	Drinking Water	Grab	06/25/25 05:13	06/30/25 18:25
122A	S5F0629-45	Drinking Water	Grab	06/25/25 05:14	06/30/25 18:25
F-7	S5F0629-46	Drinking Water	Grab	06/25/25 05:15	06/30/25 18:25
F-8	S5F0629-47	Drinking Water	Grab	06/25/25 05:16	06/30/25 18:25
BOT-4	S5F0629-48	Drinking Water	Grab	06/25/25 05:17	06/30/25 18:25
201A	S5F0629-49	Drinking Water	Grab	06/25/25 05:18	06/30/25 18:25
LIBF	S5F0629-50	Drinking Water	Grab	06/25/25 05:19	06/30/25 18:25
200A	S5F0629-51	Drinking Water	Grab	06/25/25 05:20	06/30/25 18:25
203A	S5F0629-52	Drinking Water	Grab	06/25/25 05:21	06/30/25 18:25
205A	S5F0629-53	Drinking Water	Grab	06/25/25 05:22	06/30/25 18:25
202A	S5F0629-54	Drinking Water	Grab	06/25/25 05:23	06/30/25 18:25
204A	S5F0629-55	Drinking Water	Grab	06/25/25 05:24	06/30/25 18:25
207A	S5F0629-56	Drinking Water	Grab	06/25/25 05:25	06/30/25 18:25
206A	S5F0629-57	Drinking Water	Grab	06/25/25 05:26	06/30/25 18:25
208A	S5F0629-58	Drinking Water	Grab	06/25/25 05:27	06/30/25 18:25
209A	S5F0629-59	Drinking Water	Grab	06/25/25 05:28	06/30/25 18:25
209B	S5F0629-60	Drinking Water	Grab	06/25/25 05:29	06/30/25 18:25
209C	S5F0629-61	Drinking Water	Grab	06/25/25 05:30	06/30/25 18:25



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Analytical Testing Parameters

Client Sample ID: KIT 1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-01		Collection Date: 06/25/2025 4:30

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00164	0.00500 AL	0.000400	mg/L		08/19/25 1650	08/20/25 1510	JXY

Client Sample ID: KIT 2	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-02		Collection Date: 06/25/2025 4:31

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00190	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1311	JXY

Client Sample ID: KIT 3	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-03		Collection Date: 06/25/2025 4:32

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00226	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1316	JXY

Client Sample ID: STE 1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-04		Collection Date: 06/25/2025 4:33

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000570	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1318	JXY

Client Sample ID: BOT 1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-05		Collection Date: 06/25/2025 4:34

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1320	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: F-1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-06		Collection Date: 06/25/2025 4:35

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1327	JXY

Client Sample ID: F-2	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-07		Collection Date: 06/25/2025 4:36

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1329	JXY

Client Sample ID: 104A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-08		Collection Date: 06/25/2025 4:37

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00118	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1330	JXY

Client Sample ID: 104B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-09		Collection Date: 06/25/2025 4:38

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1332	JXY

Client Sample ID: 107A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-10		Collection Date: 06/25/2025 4:38

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00170	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1334	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 107B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-11		Collection Date: 06/25/2025 4:40

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00161	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1335	JXY

Client Sample ID: 102A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-12		Collection Date: 06/25/2025 4:41

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00226	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1337	JXY

Client Sample ID: 102B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-13		Collection Date: 06/25/2025 4:42

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000477	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1339	JXY

Client Sample ID: 105A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-14		Collection Date: 06/25/2025 4:43

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00187	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1341	JXY

Client Sample ID: 105B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-15		Collection Date: 06/25/2025 4:44

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000715	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1342	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 103A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-16		Collection Date: 06/25/2025 4:45

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00537	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1356	JXY

Client Sample ID: 103B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-17		Collection Date: 06/25/2025 4:46

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00434	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1358	JXY

Client Sample ID: NUR	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-18		Collection Date: 06/25/2025 4:47

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00253	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1400	JXY

Client Sample ID: 101A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-19		Collection Date: 06/25/2025 4:48

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00204	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1402	JXY

Client Sample ID: 101B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-20		Collection Date: 06/25/2025 4:49

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000460	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1403	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: F-3	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-21		Collection Date: 06/25/2025 4:50

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1137	08/06/25 1405	JXY

Client Sample ID: BOT-2	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-22		Collection Date: 06/25/2025 4:51

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1421	JXY

Client Sample ID: F-4	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-23		Collection Date: 06/25/2025 4:52

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1426	JXY

Client Sample ID: FAC1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-24		Collection Date: 06/25/2025 4:53

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00299	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1428	JXY

Client Sample ID: 113A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-25		Collection Date: 06/25/2025 4:54

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0712	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1429	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 113B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-26		Collection Date: 06/25/2025 4:55

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000891	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1431	JXY

Client Sample ID: 115A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-27		Collection Date: 06/25/2025 4:56

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00131	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1433	JXY

Client Sample ID: 115B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-28		Collection Date: 06/25/2025 4:57

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1434	JXY

Client Sample ID: 110A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-29		Collection Date: 06/25/2025 4:58

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00153	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1436	JXY

Client Sample ID: 110B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-30		Collection Date: 06/25/2025 4:58

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1443	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 117A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-31		Collection Date: 06/25/2025 5:00

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00217	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1445	JXY

Client Sample ID: 117B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-32		Collection Date: 06/25/2025 5:01

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1447	JXY

Client Sample ID: 112A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-33		Collection Date: 06/25/2025 5:02

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00173	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1448	JXY

Client Sample ID: 112B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-34		Collection Date: 06/25/2025 5:03

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1450	JXY

Client Sample ID: 114A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-35		Collection Date: 06/25/2025 5:03

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0148	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1452	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 114B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-36		Collection Date: 06/25/2025 5:05

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000568	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1454	JXY

Client Sample ID: BOT-3	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-37		Collection Date: 06/25/2025 5:06

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1455	JXY

Client Sample ID: F-5	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-38		Collection Date: 06/25/2025 5:07

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1457	JXY

Client Sample ID: F-6	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-39		Collection Date: 06/25/2025 5:08

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1459	JXY

Client Sample ID: 121A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-40		Collection Date: 06/25/2025 5:09

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00480	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1506	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 118A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-41		Collection Date: 06/25/2025 5:10

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00868	0.00500 AL	0.000400	mg/L		08/06/25 1139	08/06/25 1508	JXY

Client Sample ID: 123A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-42		Collection Date: 06/25/2025 5:11

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00816	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1518	JXY

Client Sample ID: 120A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-43		Collection Date: 06/25/2025 5:12

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00611	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1523	JXY

Client Sample ID: 125A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-44		Collection Date: 06/25/2025 5:13

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.175	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1530	JXY

Client Sample ID: 122A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-45		Collection Date: 06/25/2025 5:14

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00804	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1532	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: F-7	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-46		Collection Date: 06/25/2025 5:15

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1534	JXY

Client Sample ID: F-8	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-47		Collection Date: 06/25/2025 5:16

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1535	JXY

Client Sample ID: BOT-4	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-48		Collection Date: 06/25/2025 5:17

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1537	JXY

Client Sample ID: 201A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-49		Collection Date: 06/25/2025 5:18

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0147	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1539	JXY

Client Sample ID: LIBF	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-50		Collection Date: 06/25/2025 5:19

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00228	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1540	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 200A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-51		Collection Date: 06/25/2025 5:20

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00370	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1542	JXY

Client Sample ID: 203A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-52		Collection Date: 06/25/2025 5:21

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000598	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1544	JXY

Client Sample ID: 205A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-53		Collection Date: 06/25/2025 5:22

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00424	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1546	JXY

Client Sample ID: 202A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-54		Collection Date: 06/25/2025 5:23

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00881	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1553	JXY

Client Sample ID: 204A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-55		Collection Date: 06/25/2025 5:24

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00840	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1554	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 207A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-56		Collection Date: 06/25/2025 5:25

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00475	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1556	JXY

Client Sample ID: 206A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-57		Collection Date: 06/25/2025 5:26

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00535	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1558	JXY

Client Sample ID: 208A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-58		Collection Date: 06/25/2025 5:27

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0265	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1600	JXY

Client Sample ID: 209A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-59		Collection Date: 06/25/2025 5:28

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00113	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1601	JXY

Client Sample ID: 209B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5F0629-60		Collection Date: 06/25/2025 5:28

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000651	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1603	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0629

Client Sample ID: 209C	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 06/25/2025 5:30
Lab Sample ID: S5F0629-61	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00176	0.00500 AL	0.000400	mg/L		08/06/25 1141	08/06/25 1605	JXY

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler **Temp:** °C

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	Yes
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	Yes
VOA vials have zero headspace, or not recd.?	Yes		


Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.**

Reviewed and Approved By:



Renee Lantz
Customer Relationship Specialist
Reported: 08/26/2025 20:03



3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.868.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: Mail Fax E-mail

Project: **2005 COMPLIANCE**

Location: **CENTER STREET**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: **CRT HBG PTN SAY**
Holding Time:

Samples Received on Ice? Yes No **N/A**

Custody Seals Intact? Yes No **N/A**

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Send Invoice via: Mail Fax E-mail

PO No.: **25-02362**

Compliance Monitoring? Yes No

If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:



S 5 F 0 6 2 9
Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Addit
	KIT-1	6/25/25	4:30	1	DW	Grab	1	LEAD IN DRINKING WATER	
	KIT-2	6/25/25	4:31	1	DW	Grab	1		
	KIT-3	6/25/25	4:32	1	DW	Grab	1		
	STE-1	6/25/25	4:33	1	DW	Grab	1		
	BOT-1	6/25/25	4:34	1	DW	Grab	1		
	F-1	6/25/25	4:35	1	DW	Grab	1		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)
Antony P. Stager

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time
6/27/25 2:10

Date/Time

Date/Time

Date/Time

Received By (signature)
Tim M

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time
6-27-25 2:10


Date/Time

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: **CRT PTN**
Samples Received on Ice? Yes No **N/A**

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.



3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Lingiestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 16640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 16840
570.898.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: () Mail () Fax (X) E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: () Mail () Fax (X) E-mail

Turnaround Time

(X) Routine (7-10 bus. days)
() RUSH* (notify lab)

Temperature Upon Receipt (°C)
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No (NA)

Custody Seals intact? Yes No (N/A)

Report Type

(X) Results Only

() Level 1 () Level 2 () Level 3 () Level 4

() EDD

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Location: **CENTER STREET**

PO No.: **25-02362**

Compliance Monitoring? Yes No
If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Melhano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Addit
	FR	6/25/25	4:36	1	DW	Grab	I	LEAD IN DRINKING WATER	
	104A	6/25/25	4:37	1	DW	Grab	I		
	104B	6/25/25	4:38	1	DW	Grab	I		
	107A	6/25/25	4:39	1	DW	Grab	I		
	107B	6/25/25	4:40	1	DW	Grab	I		
	102A	6/25/25	4:41	1	DW	Grab	I		

Possible Hazard Identification () Hazardous () Non-Hazardous () Radioactive () Disposition as appropriate () Return () Archive

Relinquished By (signature): *Antony P. Stager*
Relinquished By (signature):

Date/Time: 6/27/25 2:0
Received By (signature): *Blimm*
Date/Time: 6/27/25 2:10
Received By (signature):

Date/Time: 6/27/25 2:10
Date/Time:

Relinquished By (signature)

Received By (signature)

Date/Time

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

*** If initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

3021 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.346.0775 (PTN) 570.886.0169 (SAY)

MICROBAC

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No *N/A*
 Custody Seals Intact? Yes No *N/A*

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Compliance Monitoring? Yes No
 If Yes: Agency/Program: *NYS DOH*

Sampler Telephone No.:
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Invoice Address
 Client Name:
 Address: *507 FLETCHER ST*
 City, State, Zip: *HORSEHEADS NY 14845*
 Contact: *TONY STAGER*
 Telephone No.: *607-795-2592*
 Report Email: *astager@gstboxes.org*
 Send Report via: Mail Fax E-mail
 Location: *CENTER STREET*
 Project: *2025 COMPLIANCE*

PO No.: *25-02362*

Sampler Signature: *A. Stager*

Sampled by (PRINT): *ANTONY P. STAGER*



Horseheads Central School District
 PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Additio
	102B	6/25/25	442	1	DW	Grab	I	LEAD IN DRINKING WATER	
	105A	6/25/25	443	1	DW	Grab	I		
	105B	6/25/25	444	1	DW	Grab	I		
	103A	6/25/25	445	1	DW	Grab	I		
	103B	6/25/25	446	1	DW	Grab	I		
	NUR	6/25/25	447	1	DW	Grab	I		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Dispose as appropriate Return Archive

Relinquished By (signature): *Anthony P. Stager* Date/Time: *6/27/25 2:10*
 Relinquished By (signature): *[Signature]* Date/Time: *[Signature]*

Received By (signature): *[Signature]* Date/Time: *[Signature]*
 Received By (signature): *[Signature]* Date/Time: *[Signature]*

Relinquished By (signature): *[Signature]* Date/Time: *[Signature]*
 Relinquished By (signature): *[Signature]* Date/Time: *[Signature]*

Comments:
*Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab*


*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No *N/A*

*** If initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Page 20 of 28

CHAIN OF CUSTODY RECORD

3821 Buck Dr.
 Cortland, NY 13045
 607.753.3403 (CRT)



4359 Linglestown Rd.
 Harrisburg, PA 17112
 717.651.9700 (HBG)

2310 Elmira St.
 Sayre, PA 18840
 570.868.0169 (SAY)

Turnaround Time: **ROUTINE (7-10 bus. days)**
 () RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
 Holding Time:

Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Report Type: **Results Only**
 () Level 1 () Level 2 () Level 3 () Level 4
 () EDD

Compliance Monitoring? **Yes** () No
 If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Send Report via: () Mail () Fax **X** E-mail

Project: **2025 COMPLIANCE** Location: **CENTER STREET** PO No.: **25-02362**

Sampled by (PRINT): **ANTONY P. STAGER** Sampler Signature: *Antony P. Stager*

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Send Invoice via: () Mail () Fax **X** E-mail

Client Name: **HORSEHEADS CSD** Address: **SOT FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845** City, State, Zip: **← SAME**

Contact: **TONY STAGER** Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org** Invoice Email:

Sample Disposition: **X** Dispose as appropriate () Return () Archive

Relinquished By (signature): *Antony P. Stager* Date/Time: **6/27/25 2:10**

Relinquished By (signature): *Tim* Date/Time: **6/27/25 2:10**

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____

Relinquished By (signature): _____ Date/Time: _____



Horseheads Central School District
 PM: Joseph Palanza

Date/Time: **6-27-25 2:10pm**
 Date/Time: _____

Date/Time: _____

Date/Time: _____

Date/Time: _____

*** TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A


*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in "Above" in Final Receiving Box.

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

CHAIN OF CUSTODY RECORD

3821 Buck Dr.
 Cortland, NY 13045
 607.753.3403 (CRT)



4359 Linglestown Rd.
 Harrisburg, PA 17112
 717.651.9700 (HBG)

428 Route 315 Hwy
 Pittston, PA 18640
 570.348.0775 (PTN)

2310 Elmira St.
 Sayre, PA 18840
 570.888.0169 (SAY)

Number
 Instructions on back

Turnaround Time

Lab Report Address
 Invoice Address

Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gsthoce.org**
 Send Report via: Mail Fax E-mail

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No
 Custody Seals Intact? Yes No

← SAME

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD


Compliance Monitoring? Yes No
 Agency/Program: **NYS DOH**

PO No.: **25-02362**
 Sampler Telephone No.:

Location: **CENTER STREET**
 Sampler Signature: **A.P. Stager**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Add
	113A	6/25/25	454	1	DW	Grab	1	LEAD IN DRINKING WATER	
	113B	6/25/25	455	1	DW	Grab	1		
	115A	6/25/25	456	1	DW	Grab	1		
	115B	6/25/25	457	1	DW	Grab	1		
	110A	6/25/25	458	1	DW	Grab	1		
	110B	6/25/25	459	1	DW	Grab	1		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive
 Relinquished By (signature): **Antony P. Stager**
 Relinquished By (signature): **[Signature]**
 Relinquished By (signature):
 Relinquished By (signature):

Comments:
Drinking water samples lead in DW analysis is Not preserved - to be preserved @ lab

Date/Time: **6/27/25 2:10**
 Date/Time: **6/27/25 2:10**
 Date/Time: **6/27/25 2:10**
 Date/Time: **6/27/25 2:10**

Received By (signature): **[Signature]**
 Received By (signature): **[Signature]**
 Received By (signature):
 Received By (signature):

*** TO BE COMPLETED BY INITIAL RECEIVING MICROBAC: Same as Above []
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC: Same as Above []
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number:
 Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAV
 Holding Time:

Samples Received on Ice? Yes No
 Custody Seals Intact? Yes No

Report Type:
 Results Only

Level 1 Level 2 Level 3 Level 4
 EDD

Turnaround Time:
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address:
 Client Name:

Address:
 City, State, Zip:

Contact:
 Telephone No.:

Report Email:
 Send Report via:

Project:
 Sampled by (PRINT):

Matrix Types:
 Preservative Types:

Compliance Monitoring?
 Agency/Program:

3821 Buok Dr.
 Cortland, NY 13045
 607.753.3403 (CRT)

4359 Lingiestown Rd.
 Harrisburg, PA 17112
 717.651.9700 (HBG)

2310 Elmira St.
 Sayre, PA 18840
 570.888.0169 (SAY)

428 Route 315 Hwy
 Pittston, PA 18640
 570.348.0775 (PTN)

507 FLETCHER ST
 HORSEHEADS NY 14845

TONY STAGER
 607-795-2592
 astager@gstbores.org

ANTONY P. STAGER
 2025 COMPLIANCE

Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Center Street
 A. Stager

PO No.: 25-02362

Sampler Telephone No.:

Requested Analysis:

Sample Disposition:
 Dispose as appropriate Return Archive

Relinquished By (signature):
 Relinquished By (signature):

Relinquished By (signature):
 Relinquished By (signature):

Date/Time:
 Date/Time:

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Time Collected

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers

Lab ID

Client Sample ID

Date Collected

Time Collected

Sample Disposition

Date/Time

Date/Time

Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

3025 COMPLIANCE

Antony P. Stager

Center Street

Drinking Water

Grab / Composite

Matrix *

No. of Containers



Horseheads Central School District
PM: Joseph Palanza

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
 Holding Time:

Samples Received on Ice? Yes No **N/A**
 Custody Seals Intact? Yes No **N/A**

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Compliance Monitoring? Yes No
 Agency/Program: **NYS DOH**

Sampler Telephone No.:

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District

PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Additio
	120A	6/25/25	5:12	1	DW	Grab	1	LEAD IN DRINKING WATER	
	125A	6/25/25	5:13	1	DW	Grab	1		
	122A	6/25/25	5:14	1	DW	Grab	1		
	F-7	6/25/25	5:15	1	DW	Grab	1		
	F-8	6/25/25	5:16	1	DW	Grab	1		
	BOT-4	6/25/25	5:17	1	DW	Grab	1		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature): *Antony P. Stager*
 Relinquished By (signature): *Antony P. Stager*

Date/Time: 6/27/25 2:10
 Received By (signature): *MM*
 Date/Time: 6/27/25 2:10
 Received By (signature): *MM*

Date/Time: 6-27-25 2:10pm
 Date/Time: 6-27-25 2:10pm

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time


Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittaton, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)



Instructions on back

Turnaround Time


Invoice Address

Lab Report Address

Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gsthoce.org**
 Send Report via: Mail Fax E-mail
 Client Name: **← SAME**
 Address: **← SAME**
 City, State, Zip: **← SAME**
 Contact: **← SAME**
 Telephone No.: **← SAME**

Project: **2025 COMPLIANCE** Location: **CENTER STREET** PO No.: **25-02362** Compliance Monitoring? Yes No
 Agency/Program: **NYS DOH**

Sampled by (PRINT): **ANTHONY P. STAGER** Sampler Signature: *Anthony P. Stager* Sampler Telephone No.:
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Add
	201A	6/25/25	5:18	1	DW	Grab	1	LEAD IN DRINKING WATER	
	LIBF	6/25/25	5:19	1	DW	Grab	1		
	200A	6/25/25	5:20	1	DW	Grab	1		
	203A	6/25/25	5:21	1	DW	Grab	1		
	205A	6/25/25	5:22	1	DW	Grab	1		
	202A	6/25/25	5:23	1	DW	Grab	1		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature): *Anthony P. Stager* Date/Time: **6/27/25 2:00 PM**
 Relinquished By (signature): *[Signature]* Date/Time:
 Relinquished By (signature): *[Signature]* Date/Time:
 Relinquished By (signature): *[Signature]* Date/Time:

Comments:
Drinking water samples
Lead in DW analysis
Not preserved - to be preserved @ lab

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in "Requested Analysis" column.
 *** TO BE COMPLETED BY FINAL RECEIVING MICROBAC: Same as Above
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back


TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)



Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Sampler Signature:

Sampler Telephone No.:

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Report Type


Results Only

Level 1 Level 2 Level 3 Level 4

EDD

PO No.: 25-02362 Compliance Monitoring? Yes No
If Yes: Agency/Program: **MS DO**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Ad
	204A	6/25/25	5:24	1	DW	Grab	I	LEAD IN DRINKING WATER	
	207A	6/25/25	5:25	1	DW	Grab	I		
	206A	6/25/25	5:26	1	DW	Grab	I		
	208A	6/25/25	5:27	1	DW	Grab	I		
	209A	6/25/25	5:28	1	DW	Grab	I		
	209B	6/25/25	5:29	1	DW	Grab	I		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive
Received By (signature) *Anthony P. Stager* Date/Time 6/27/25 2:10
Received By (signature) *Tim* Date/Time 6/27/25 2:10

Date/Time 6/27/25 2:10pm
Date/Time 6/27/25 2:10pm

Relinquished By (signature) *Anthony P. Stager* Date/Time
Relinquished By (signature) Date/Time
Relinquished By (signature) Date/Time

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC: ***

Temperature Upon Receipt (°C): Same as Above []

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Report Type
Results Only

Level 1 Level 2 Level 3 Level 4
EDD

Compliance Monitoring? Yes No
Agency/Program: **MS DA**

MICROBAC

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Eimira St.
Sayre, PA 18840
570.899.0169 (SAY)

Invoice Address

Client Name:
Address:
City, State, Zip:
Contact:
Telephone No.:

Send Report via: Mail Fax E-mail

Send Invoice via: Mail Fax E-mail

LAB REPORT ADDRESS

Client Name:
Address:
City, State, Zip:
Contact:
Telephone No.:

Send Report via: Mail Fax E-mail

Send Invoice via: Mail Fax E-mail

Location: **CENTER STREET**

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTHONY P. STAGER**

Sampler Signature: *Anthony P. Stager*

Sampler Telephone No.:

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Requested Analysis

Possible Hazard Identification

Comments:

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Lab ID

Client Sample ID

Date Collected

Time Collected

No. of Containers

Matrix *

Grab / Composite

Preservative **

Requested Analysis

Possible Hazard Identification

Sample Disposition

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Date/Time

Date/Time

Date/Time

Comments:

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Drinking water samples

Lead in DW analysis

Not preserved - to be preserved @ lab

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Date/Time

Date/Time

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

Compliance Monitoring? Yes No

Agency/Program: **MS DA**

Sampler Telephone No.:

Requested Analysis

Possible Hazard Identification

Comments:

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

Compliance Monitoring? Yes No

Agency/Program: **MS DA**

Sampler Telephone No.:

Requested Analysis

Possible Hazard Identification

Comments:

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

Compliance Monitoring? Yes No

Agency/Program: **MS DA**

Sampler Telephone No.:

Requested Analysis

Possible Hazard Identification

Comments:

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

Compliance Monitoring? Yes No

Agency/Program: **MS DA**

Sampler Telephone No.:

Requested Analysis


Possible Hazard Identification

Comments:

Relinquished By (signature)

Relinquished By (signature)

Date/Time



Horseheads Central School District
PM: Joseph Palanza

Date/Time: 6-27-25
Date/Time: 2:10 PM

Date/Time: 6-27-25
Date/Time: 2:10 PM

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN