



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Project Description

Intermediate School

For:

Michael Coghlan

Horseheads Central School District

507 Fletcher Street

Horseheads, NY 14845

Service Center Manager

Joseph Palanza

Wednesday, December 31, 2025

Please find enclosed the analytical results for the samples you submitted to Microbac Laboratories. Review and compilation of your report was completed by Microbac Laboratories, Inc., Sayre Division. If you have any questions, comments, or require further assistance regarding this report, please contact your service representative listed above.

I certify that all test results meet all of the requirements of the accrediting authority listed within this report. Analytical results are reported on a 'as received' basis unless specified otherwise. Analytical results for solids with units ending in (dry) are reported on a dry weight basis. A statement of uncertainty for each analysis is available upon request. This laboratory report shall not be reproduced, except in full, without the written approval of Microbac Laboratories. The reported results are related only to the samples analyzed as received.

Microbac Laboratories, Inc.

2310 Elmira Street | Sayre, PA 18840 | 570-888-0169 p | www.microbac.com



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Horseheads Central School District

Project Name: Intermediate School

Michael Coghlan
507 Fletcher Street
Horseheads, NY 14845

Project / PO Number: 25-02362
Received: 11/30/2025
Reported: 12/31/2025

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
KIT1	S5K0535-01	Drinking Water	Grab		11/14/25 04:45	11/30/25 21:41
KIT2	S5K0535-02	Drinking Water	Grab		11/14/25 04:46	11/30/25 21:41
KIT4	S5K0535-03	Drinking Water	Grab		11/14/25 04:47	11/30/25 21:41
KIT6	S5K0535-04	Drinking Water	Grab		11/14/25 04:48	11/30/25 21:41
STEAM1	S5K0535-05	Drinking Water	Grab		11/14/25 04:49	11/30/25 21:41
STEAM2	S5K0535-06	Drinking Water	Grab		11/14/25 04:50	11/30/25 21:41
FNT1	S5K0535-07	Drinking Water	Grab		11/14/25 04:51	11/30/25 21:41
FNT2	S5K0535-08	Drinking Water	Grab		11/14/25 04:52	11/30/25 21:41
BOT1	S5K0535-09	Drinking Water	Grab		11/14/25 04:53	11/30/25 21:41
BOT2	S5K0535-10	Drinking Water	Grab		11/14/25 04:54	11/30/25 21:41
FNT3	S5K0535-11	Drinking Water	Grab		11/14/25 04:55	11/30/25 21:41
FNT4	S5K0535-12	Drinking Water	Grab		11/14/25 04:56	11/30/25 21:41
332F	S5K0535-13	Drinking Water	Grab		11/14/25 04:57	11/30/25 21:41
FNT5	S5K0535-14	Drinking Water	Grab		11/14/25 04:58	11/30/25 21:41
FNT6	S5K0535-15	Drinking Water	Grab		11/14/25 04:59	11/30/25 21:41
BOT3	S5K0535-16	Drinking Water	Grab		11/14/25 05:00	11/30/25 21:41
BOT4	S5K0535-17	Drinking Water	Grab		11/14/25 05:01	11/30/25 21:41
FNT7	S5K0535-18	Drinking Water	Grab		11/14/25 05:02	11/30/25 21:41
FNT8	S5K0535-19	Drinking Water	Grab		11/14/25 05:03	11/30/25 21:41
FNT9	S5K0535-20	Drinking Water	Grab		11/14/25 05:04	11/30/25 21:41
FNT10	S5K0535-21	Drinking Water	Grab		11/14/25 05:05	11/30/25 21:41
BOT5	S5K0535-22	Drinking Water	Grab		11/14/25 05:06	11/30/25 21:41
405F	S5K0535-23	Drinking Water	Grab		11/14/25 05:07	11/30/25 21:41
407F	S5K0535-24	Drinking Water	Grab		11/14/25 05:08	11/30/25 21:41
407B	S5K0535-25	Drinking Water	Grab		11/14/25 05:09	11/30/25 21:41
409F	S5K0535-26	Drinking Water	Grab		11/14/25 05:10	11/30/25 21:41
409B	S5K0535-27	Drinking Water	Grab		11/14/25 05:11	11/30/25 21:41
411F	S5K0535-28	Drinking Water	Grab		11/14/25 05:12	11/30/25 21:41
411B	S5K0535-29	Drinking Water	Grab		11/14/25 05:13	11/30/25 21:41
413F	S5K0535-30	Drinking Water	Grab		11/14/25 05:14	11/30/25 21:41
413B	S5K0535-31	Drinking Water	Grab		11/14/25 05:15	11/30/25 21:41
415F	S5K0535-32	Drinking Water	Grab		11/14/25 05:16	11/30/25 21:41
415B	S5K0535-33	Drinking Water	Grab		11/14/25 05:17	11/30/25 21:41
417F	S5K0535-34	Drinking Water	Grab		11/14/25 05:18	11/30/25 21:41
417B	S5K0535-35	Drinking Water	Grab		11/14/25 05:19	11/30/25 21:41
327F	S5K0535-36	Drinking Water	Grab		11/14/25 05:20	11/30/25 21:41
327B	S5K0535-37	Drinking Water	Grab		11/14/25 05:21	11/30/25 21:41
325F	S5K0535-38	Drinking Water	Grab		11/14/25 05:22	11/30/25 21:41
325B	S5K0535-39	Drinking Water	Grab		11/14/25 05:23	11/30/25 21:41

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
330F	S5K0535-40	Drinking Water	Grab		11/14/25 05:24	11/30/25 21:41
330B	S5K0535-41	Drinking Water	Grab		11/14/25 05:25	11/30/25 21:41
323F	S5K0535-42	Drinking Water	Grab		11/14/25 05:26	11/30/25 21:41
323B	S5K0535-43	Drinking Water	Grab		11/14/25 05:27	11/30/25 21:41
321F	S5K0535-44	Drinking Water	Grab		11/14/25 05:28	11/30/25 21:41
321B	S5K0535-45	Drinking Water	Grab		11/14/25 05:29	11/30/25 21:41
326F	S5K0535-46	Drinking Water	Grab		11/14/25 05:30	11/30/25 21:41
326B	S5K0535-47	Drinking Water	Grab		11/14/25 05:31	11/30/25 21:41
319F	S5K0535-48	Drinking Water	Grab		11/14/25 05:32	11/30/25 21:41
319B	S5K0535-49	Drinking Water	Grab		11/14/25 05:33	11/30/25 21:41
317F	S5K0535-50	Drinking Water	Grab		11/14/25 05:34	11/30/25 21:41
317B	S5K0535-51	Drinking Water	Grab		11/14/25 05:35	11/30/25 21:41
324F	S5K0535-52	Drinking Water	Grab		11/14/25 05:36	11/30/25 21:41
324B	S5K0535-53	Drinking Water	Grab		11/14/25 05:37	11/30/25 21:41
322F	S5K0535-54	Drinking Water	Grab		11/14/25 05:38	11/30/25 21:41
322B	S5K0535-55	Drinking Water	Grab		11/14/25 05:39	11/30/25 21:41
AISF	S5K0535-56	Drinking Water	Grab		11/14/25 05:40	11/30/25 21:41
320F	S5K0535-57	Drinking Water	Grab		11/14/25 05:41	11/30/25 21:41
320B	S5K0535-58	Drinking Water	Grab		11/14/25 05:42	11/30/25 21:41
318F	S5K0535-59	Drinking Water	Grab		11/14/25 05:43	11/30/25 21:41
318B	S5K0535-60	Drinking Water	Grab		11/14/25 05:44	11/30/25 21:41
316F	S5K0535-61	Drinking Water	Grab		11/14/25 05:45	11/30/25 21:41
316B	S5K0535-62	Drinking Water	Grab		11/14/25 05:46	11/30/25 21:41
314F	S5K0535-63	Drinking Water	Grab		11/14/25 05:47	11/30/25 21:41
314B	S5K0535-64	Drinking Water	Grab		11/14/25 05:48	11/30/25 21:41
315A	S5K0535-65	Drinking Water	Grab		11/14/25 05:49	11/30/25 21:41
315B	S5K0535-66	Drinking Water	Grab		11/14/25 05:50	11/30/25 21:41
313A	S5K0535-67	Drinking Water	Grab		11/14/25 05:51	11/30/25 21:41
313B	S5K0535-68	Drinking Water	Grab		11/14/25 05:52	11/30/25 21:41
FACCON2	S5K0535-69	Drinking Water	Grab		11/14/25 05:53	11/30/25 21:41
312F	S5K0535-70	Drinking Water	Grab		11/14/25 05:54	11/30/25 21:41
312B	S5K0535-71	Drinking Water	Grab		11/14/25 05:55	11/30/25 21:41
310F	S5K0535-72	Drinking Water	Grab		11/14/25 05:56	11/30/25 21:41
310B	S5K0535-73	Drinking Water	Grab		11/14/25 05:57	11/30/25 21:41
308F	S5K0535-74	Drinking Water	Grab		11/14/25 05:58	11/30/25 21:41
308B	S5K0535-75	Drinking Water	Grab		11/14/25 05:59	11/30/25 21:41
306F	S5K0535-76	Drinking Water	Grab		11/14/25 06:00	11/30/25 21:41
608B	S5K0535-77	Drinking Water	Grab		11/14/25 06:01	11/30/25 21:41
604F	S5K0535-78	Drinking Water	Grab		11/14/25 06:02	11/30/25 21:41
304B	S5K0535-79	Drinking Water	Grab		11/14/25 06:03	11/30/25 21:41
302F	S5K0535-80	Drinking Water	Grab		11/14/25 06:04	11/30/25 21:41
302B	S5K0535-81	Drinking Water	Grab		11/14/25 06:05	11/30/25 21:41
311F	S5K0535-82	Drinking Water	Grab		11/14/25 06:06	11/30/25 21:41
311B	S5K0535-83	Drinking Water	Grab		11/14/25 06:07	11/30/25 21:41
309F	S5K0535-84	Drinking Water	Grab		11/14/25 06:08	11/30/25 21:41
309B	S5K0535-85	Drinking Water	Grab		11/14/25 06:09	11/30/25 21:41
300F	S5K0535-86	Drinking Water	Grab		11/14/25 06:10	11/30/25 21:41
307F	S5K0535-87	Drinking Water	Grab		11/14/25 06:11	11/30/25 21:41
307B	S5K0535-88	Drinking Water	Grab		11/14/25 06:12	11/30/25 21:41
305F	S5K0535-89	Drinking Water	Grab		11/14/25 06:13	11/30/25 21:41
305B	S5K0535-90	Drinking Water	Grab		11/14/25 06:14	11/30/25 21:41
303F	S5K0535-91	Drinking Water	Grab		11/14/25 06:15	11/30/25 21:41

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
303B	S5K0535-92	Drinking Water	Grab		11/14/25 06:16	11/30/25 21:41
301F	S5K0535-93	Drinking Water	Grab		11/14/25 06:17	11/30/25 21:41
301B	S5K0535-94	Drinking Water	Grab		11/14/25 06:18	11/30/25 21:41
MOF	S5K0535-95	Drinking Water	Grab		11/14/25 06:19	11/30/25 21:41
SOC1	S5K0535-96	Drinking Water	Grab		11/14/25 06:20	11/30/25 21:41
SOC2	S5K0535-97	Drinking Water	Grab		11/14/25 06:21	11/30/25 21:41
ISGYMF	S5K0535-98	Drinking Water	Grab		11/14/25 06:22	11/30/25 21:41
BOT6	S5K0535-99	Drinking Water	Grab		11/14/25 06:23	11/30/25 21:41
FNT11	S5K0535-AA	Drinking Water	Grab		11/14/25 06:24	11/30/25 21:41
ICE	S5K0535-AB	Drinking Water	Grab		11/14/25 06:25	11/30/25 21:41



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Analytical Testing Parameters

Client Sample ID: KIT1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-01		Collection Date: 11/14/2025 4:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1549	DLO

Client Sample ID: KIT2	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-02		Collection Date: 11/14/2025 4:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0004	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1553	DLO

Client Sample ID: KIT4	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-03		Collection Date: 11/14/2025 4:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1555	DLO

Client Sample ID: KIT6	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-04		Collection Date: 11/14/2025 4:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1556	DLO

Client Sample ID: STEAM1	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-05		Collection Date: 11/14/2025 4:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1558	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: STEAM2	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 4:50
Lab Sample ID: S5K0535-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0006	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1559	DLO

Client Sample ID: FNT1	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 4:51
Lab Sample ID: S5K0535-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1604	DLO

Client Sample ID: FNT2	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 4:52
Lab Sample ID: S5K0535-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1605	DLO

Client Sample ID: BOT1	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 4:53
Lab Sample ID: S5K0535-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1607	DLO

Client Sample ID: BOT2	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 4:54
Lab Sample ID: S5K0535-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1609	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: FNT3	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-11		Collection Date: 11/14/2025 4:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1610	DLO

Client Sample ID: FNT4	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-12		Collection Date: 11/14/2025 4:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1613	DLO

Client Sample ID: 332F	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-13		Collection Date: 11/14/2025 4:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0007	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1510	12/16/25 1615	DLO

Client Sample ID: FNT5	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-14		Collection Date: 11/14/2025 4:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1616	DLO

Client Sample ID: FNT6	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-15		Collection Date: 11/14/2025 4:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1618	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: BOT3	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:00
Lab Sample ID: S5K0535-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1622	DLO

Client Sample ID: BOT4	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:01
Lab Sample ID: S5K0535-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1624	DLO

Client Sample ID: FNT7	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:02
Lab Sample ID: S5K0535-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1626	DLO

Client Sample ID: FNT8	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:03
Lab Sample ID: S5K0535-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1627	DLO

Client Sample ID: FNT9	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:04
Lab Sample ID: S5K0535-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1510	12/16/25 1629	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: FNT10	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:05
Lab Sample ID: S5K0535-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1636	DLO

Client Sample ID: BOT5	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:06
Lab Sample ID: S5K0535-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1641	DLO

Client Sample ID: 405F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:07
Lab Sample ID: S5K0535-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0137	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1643	DLO

Client Sample ID: 407F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:08
Lab Sample ID: S5K0535-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0025	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1644	DLO

Client Sample ID: 407B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:09
Lab Sample ID: S5K0535-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1646	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 409F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:10
Lab Sample ID: S5K0535-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0026	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1647	DLO

Client Sample ID: 409B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:11
Lab Sample ID: S5K0535-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0001	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1652	DLO

Client Sample ID: 411F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:12
Lab Sample ID: S5K0535-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0012	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1653	DLO

Client Sample ID: 411B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:13
Lab Sample ID: S5K0535-29	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1655	DLO

Client Sample ID: 413F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:14
Lab Sample ID: S5K0535-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0009	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1657	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 413B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:15
Lab Sample ID: S5K0535-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1658	DLO

Client Sample ID: 415F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:16
Lab Sample ID: S5K0535-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0005	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1701	DLO

Client Sample ID: 415B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:17
Lab Sample ID: S5K0535-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1703	DLO

Client Sample ID: 417F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:18
Lab Sample ID: S5K0535-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0029	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1704	DLO

Client Sample ID: 417B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:19
Lab Sample ID: S5K0535-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00008	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1706	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 327F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:20
Lab Sample ID: S5K0535-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0039	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1711	DLO

Client Sample ID: 327B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:21
Lab Sample ID: S5K0535-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0015	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1712	DLO

Client Sample ID: 325F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:22
Lab Sample ID: S5K0535-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0021	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1714	DLO

Client Sample ID: 325B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:23
Lab Sample ID: S5K0535-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1511	12/16/25 1715	DLO

Client Sample ID: 330F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:24
Lab Sample ID: S5K0535-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0020	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1511	12/16/25 1717	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 330B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:25
Lab Sample ID: S5K0535-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0005	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1724	DLO

Client Sample ID: 323F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:26
Lab Sample ID: S5K0535-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0099	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1729	DLO

Client Sample ID: 323B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:27
Lab Sample ID: S5K0535-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0004	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1731	DLO

Client Sample ID: 321F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:28
Lab Sample ID: S5K0535-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0026	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1732	DLO

Client Sample ID: 321B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:29
Lab Sample ID: S5K0535-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0005	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1734	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 326F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:30
Lab Sample ID: S5K0535-46	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0031	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1735	DLO

Client Sample ID: 326B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:31
Lab Sample ID: S5K0535-47	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0001	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1740	DLO

Client Sample ID: 319F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:32
Lab Sample ID: S5K0535-48	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0046	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1742	DLO

Client Sample ID: 319B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:33
Lab Sample ID: S5K0535-49	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0007	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1743	DLO

Client Sample ID: 317F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:34
Lab Sample ID: S5K0535-50	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0022	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1745	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 317B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:35
Lab Sample ID: S5K0535-51	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1746	DLO

Client Sample ID: 324F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:36
Lab Sample ID: S5K0535-52	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0279	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1749	DLO

Client Sample ID: 324B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:37
Lab Sample ID: S5K0535-53	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0007	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1751	DLO

Client Sample ID: 322F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:38
Lab Sample ID: S5K0535-54	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0046	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1752	DLO

Client Sample ID: 322B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:39
Lab Sample ID: S5K0535-55	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1754	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: AISF	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:40
Lab Sample ID: S5K0535-56	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0005	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1759	DLO

Client Sample ID: 320F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:41
Lab Sample ID: S5K0535-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0674	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1800	DLO

Client Sample ID: 320B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:42
Lab Sample ID: S5K0535-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1802	DLO

Client Sample ID: 318F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:43
Lab Sample ID: S5K0535-59	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0054	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1529	12/16/25 1803	DLO

Client Sample ID: 318B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:44
Lab Sample ID: S5K0535-60	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1529	12/16/25 1805	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 316F	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-61		Collection Date: 11/14/2025 5:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0085	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1812	DLO

Client Sample ID: 316B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-62		Collection Date: 11/14/2025 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0001	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1817	DLO

Client Sample ID: 314F	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-63		Collection Date: 11/14/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0043	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1819	DLO

Client Sample ID: 314B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-64		Collection Date: 11/14/2025 5:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1820	DLO

Client Sample ID: 315A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-65		Collection Date: 11/14/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0006	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1822	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 315B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:50
Lab Sample ID: S5K0535-66	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0014	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1823	DLO

Client Sample ID: 313A	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:51
Lab Sample ID: S5K0535-67	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0012	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1828	DLO

Client Sample ID: 313B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:52
Lab Sample ID: S5K0535-68	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0012	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1829	DLO

Client Sample ID: FACCON2	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:53
Lab Sample ID: S5K0535-69	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0021	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1831	DLO

Client Sample ID: 312F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:54
Lab Sample ID: S5K0535-70	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0040	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1833	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 312B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:55
Lab Sample ID: S5K0535-71	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0006	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1834	DLO

Client Sample ID: 310F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:56
Lab Sample ID: S5K0535-72	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0039	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1837	DLO

Client Sample ID: 310B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:57
Lab Sample ID: S5K0535-73	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0003	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1839	DLO

Client Sample ID: 308F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:58
Lab Sample ID: S5K0535-74	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0131	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1840	DLO

Client Sample ID: 308B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 5:59
Lab Sample ID: S5K0535-75	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0008	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1842	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 306F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:00
Lab Sample ID: S5K0535-76	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0047	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1846	DLO

Client Sample ID: 608B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:01
Lab Sample ID: S5K0535-77	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00009	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1848	DLO

Client Sample ID: 604F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:02
Lab Sample ID: S5K0535-78	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0062	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1850	DLO

Client Sample ID: 304B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:03
Lab Sample ID: S5K0535-79	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/16/25 1530	12/16/25 1851	DLO

Client Sample ID: 302F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:04
Lab Sample ID: S5K0535-80	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0039	0.0050 AL	0.00006	0.0010	mg/L		12/16/25 1530	12/16/25 1853	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 302B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-81		Collection Date: 11/14/2025 6:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1653	DLO

Client Sample ID: 311F	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-82		Collection Date: 11/14/2025 6:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0077	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1657	DLO

Client Sample ID: 311B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-83		Collection Date: 11/14/2025 6:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0004	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1659	DLO

Client Sample ID: 309F	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-84		Collection Date: 11/14/2025 6:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0062	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1700	DLO

Client Sample ID: 309B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0535-85		Collection Date: 11/14/2025 6:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1702	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 300F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:10
Lab Sample ID: S5K0535-86	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0057	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1704	DLO

Client Sample ID: 307F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:11
Lab Sample ID: S5K0535-87	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0048	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1708	DLO

Client Sample ID: 307B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:12
Lab Sample ID: S5K0535-88	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1709	DLO

Client Sample ID: 305F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:13
Lab Sample ID: S5K0535-89	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0055	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1711	DLO

Client Sample ID: 305B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:14
Lab Sample ID: S5K0535-90	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1713	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: 303F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:15
Lab Sample ID: S5K0535-91	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0197	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1714	DLO

Client Sample ID: 303B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:16
Lab Sample ID: S5K0535-92	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0002	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1717	DLO

Client Sample ID: 301F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:17
Lab Sample ID: S5K0535-93	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0051	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1718	DLO

Client Sample ID: 301B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:18
Lab Sample ID: S5K0535-94	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0001	0.0050 AL	0.00006	0.0010	mg/L	J	12/15/25 1547	12/15/25 1720	DLO

Client Sample ID: MOF	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:18
Lab Sample ID: S5K0535-95	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0028	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1722	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: SOC1	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:20
Lab Sample ID: S5K0535-96	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0033	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1726	DLO

Client Sample ID: SOC2	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:21
Lab Sample ID: S5K0535-97	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0089	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1728	DLO

Client Sample ID: ISGYMF	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:22
Lab Sample ID: S5K0535-98	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0046	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1729	DLO

Client Sample ID: BOT6	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:23
Lab Sample ID: S5K0535-99	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1547	12/15/25 1731	DLO

Client Sample ID: FNT11	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:24
Lab Sample ID: S5K0535-AA	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.00006	0.0050 AL	0.00006	0.0010	mg/L		12/15/25 1548	12/15/25 1740	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0535

Client Sample ID: ICE
Sample Matrix: Drinking Water
Lab Sample ID: S5K0535-AB
Collected By: Antony P Stager
Collection Date: 11/14/2025 6:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with columns: Metals Total by ICPMS, Result, Limit(s), MDL, RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: <0.00006, 0.0050 AL, 0.00006, 0.0010, mg/L, 12/15/25 1548, 12/15/25 1801, DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
J: Estimated value. The analyte concentration is less than the reporting/quantitation limit.
MDL: Minimum Detection Limit
mg/L: Milligrams per Liter
RL: Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Question, Yes/No, Question, Yes/No. Items include: Ice Present or not required?, Custody seals intact or not required?, COC includes customer information?, etc.

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Handwritten signature of Joseph Palanza

Joseph Palanza
Service Center Manager
Reported: 12/31/2025 18:47

CHAIN OF CUSTODY RECORD

Number: 2310 Elmira St.
 Instructions on back: Sayre, PA 18840

Turnaround Time: 570.888.0169 (SAY)

428 Route 315 Hwy
 Pittston, PA 18640

4359 Lingletstown Rd.
 Harrisburg, PA 17112

3821 Buck Dr.
 Cortland, NY 13045

607.753.3403 (CRT)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Report Type: Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Invoice Address: 570.888.0169 (SAY)

Client Name: Sayre, PA 18840

Address: 570.888.0169 (SAY)

717.651.9700 (HBG)

Address: 507 FLETCHER ST
 City, State, Zip: HORSEHEADS NY 14845
 Contact: TONY STAGER
 Telephone No.: 607-795-2592
 Report Email: astager@gstbores.org

Send Invoice via: Mail Fax E-mail

Location: INTERMEDIATE SCH.

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampled by (PRINT): ANTONY P. STAGER

PO No.: 25-02362

Compliance Monitoring? Yes No
 Agency/Program: NYS DOH

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Requested Analysis: LEAD IN DRINKING WATER

Sample Disposition: Dispose as appropriate Return Archive

Received By (signature): J. Palumy

Date/Time: 11/14/25 12:45

Relinquished By (signature): Anthony P. Stager



Horseheads Central School District
 PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Sample Disposition	Date/Time	Received By (signature)	Date/Time
	KIT 1	11/14/25	445	1	DW	Grab	I	LEAD IN DRINKING WATER	<input checked="" type="checkbox"/>		J. Palumy	11/14/25 12:45
	KIT 2	11/14/25	446	1	DW	Grab	I					
	KIT 4	11/14/25	447	1	DW	Grab	I					
	KIT 6	11/14/25	448	1	DW	Grab	I					
	STEAM 1	11/14/25	449	1	DW	Grab	I					
	STEAM 2	11/14/25	450	1	DW	Grab	I					

Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.886.0169 (SAY)

Instructions on back

Turnaround Time

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Invoice Address

Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gstbores.org**
 Send Report via: Mail Fax E-mail

← SAME

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Report Email:

Send Invoice via: Mail Fax E-mail

Location: **INTERMEDIATE SCH.** PO No.: **25-02362**

Sampler Signature: **A.P. Stager**

Compliance Monitoring? Yes No
 Agency/Program: **NYS DOH**

Sampler Telephone No.:

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipes (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	FNT 1	11/14/25	451	1	DW	Grab	1	LEAD IN DRINKING WATER
	FNT 2	11/14/25	452	1	DW	Grab	1	
	BOT 1	11/14/25	453	1	DW	Grab	1	
	BOT 2	11/14/25	454	1	DW	Grab	1	
	FNT 3	11/14/25	455	1	DW	Grab	1	
	FNT 4	11/14/25	456	1	DW	Grab	1	

Requested Analysis: **LEAD IN DRINKING WATER**

Sample Disposition: Dispose as appropriate Return Archive

Relinquished By (signature): **Anthony P. Stager** Date/Time: **11/14/25 12:45**

Received By (signature): **[Signature]** Date/Time: **11/14/25 12:45**

Comments: **Drinking water samples lead in DW analysis Not preserved - to be preserved @ lab**

Relinquished By (signature): **[Signature]** Date/Time: **11/14/25 12:45**

Received By (signature): **[Signature]** Date/Time: **11/14/25 12:45**

*** TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18940
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.886.0169 (SAY)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):

Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

PO No.: **25-02362** Compliance Monitoring? Yes No
 If Yes: Agency/Program: **NYS DOH**

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (Specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	332 F	11/14/25	457	1	DW	Grab	I	X LEAD IN DRINKING WATER
	FNT5	11/14/25	458	1	DW	Grab	I	
	FNT6	11/14/25	459	1	DW	Grab	I	
	BOT3	11/14/25	500	1	DW	Grab	I	
	BOT4	11/14/25	501	1	DW	Grab	I	
	FNT7	11/14/25	502	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature): *Antony P. Stager* Date/Time: 11/14/25 1245
 Relinquished By (signature): *[Signature]* Date/Time:
 Relinquished By (signature):
 Relinquished By (signature):

*Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab*

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C): Same as Above
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A


CHAIN OF CUSTODY RECORD

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)



Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Location: **INTERMEDIATE SCH.**

Compliance Monitoring? Yes No
If Yes: Agency/Program: **NYS DOH**

PO No.: **25-02362**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

- * Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (Specify)
- ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (Specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	FNT 8	11/14/25	503	1	DW	Grab	I	LEAD IN DRINKING WATER
	FNT 9	11/14/25	504	1	DW	Grab	I	
	FNT 10	11/14/25	505	1	DW	Grab	I	
	BOT 5	11/14/25	506	1	DW	Grab	I	
	405 F	11/14/25	507	1	DW	Grab	I	
	407 F	11/14/25	508	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Archive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature) *Antony P. Stager* Date/Time 11/14/25 12:45

Received By (signature) *J. Galluzzi* Date/Time 11/14/25 12:45

Comments:
Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840

428 Route 315 Hwy
Pittston, PA 18640

4359 Lingelstown Rd.
Harrisburg, PA 17112

3821 Buck Dr.
Cortland, NY 13045

MICROBAC
607.753.3403 (CRT)

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

← SAME

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstboxes.org**

Send Report via: Mail Fax E-mail

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Project: **2025 COMPLIANCE** Location: **INTERMEDIATE SCH.** PO No.: **25-02362** Compliance Monitoring? Yes No
If Yes: Agency/Program: **NYS DOH**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

- * Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (Specify)
- ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	407B	11/14/25	509	1	DW	Grab	I	LEAD IN DRINKING WATER
	409F	11/14/25	510	1	DW	Grab	I	
	409B	11/14/25	511	1	DW	Grab	I	
	411F	11/14/25	512	1	DW	Grab	I	
	411B	11/14/25	513	1	DW	Grab	I	
	413F	11/14/25	514	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature): *Antony P. Stager* Date/Time: 11/14/25 1245

Relinquished By (signature): *[Signature]* Date/Time: 11/14/25 1245

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C): Same as Above
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Send Invoice via: Mail Fax E-mail

Compliance Monitoring? Yes No
If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Location: **INTERMEDIATE SCH.**

PO No.: **25-02362**

Sampler Signature: **A.P. Stager**

Sampled by (PRINT): **ANTONY P. STAGER**

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	413B	11/14/25	515	1	DW	Grab	I	LEAD IN DRINKING WATER
	415F	11/14/25	516	1	DW	Grab	I	
	415B	11/14/25	517	1	DW	Grab	I	
	417F	11/14/25	518	1	DW	Grab	I	
	417B	11/14/25	519	1	DW	Grab	I	
	327F	11/14/25	520	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Received By (signature) **[Signature]**

Date/Time 11/14/25 12:45

Received By (signature) **[Signature]**

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Lingiestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.886.0169 (SAY)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address
 Client Name:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Lab Report Address
 Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gstboxes.org**
 Send Report via: Mail Fax E-mail

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

PO No.: **25-02362** Compliance Monitoring? Yes No
 Agency/Program: **NYS DOH**

Invoice Email:
 Send Invoice via: Mail Fax E-mail

Sampler Signature: **A.P. Stager** Sampler Telephone No.:
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Location: **INTERMEDIATE SCH.**

Relinquished By (signature): **Antony P. Stager**

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Relinquished By (signature): **Antony P. Stager**

Requested Analysis

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature): **Antony P. Stager**

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	327B	11/14/25	521	1	DW	Grab	I	LEAD IN DRINKING WATER
	325F	11/14/25	522	1	DW	Grab	I	
	325B	11/14/25	523	1	DW	Grab	I	
	330F	11/14/25	524	1	DW	Grab	I	
	330B	11/14/25	525	1	DW	Grab	I	
	323F	11/14/25	526	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Relinquished By (signature): **Antony P. Stager**

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to be preserved @ lab

Received By (signature): **Antony P. Stager** Date/Time: 11/14/25 12:45
 Received By (signature): Date/Time:
 Received By (signature): Date/Time:
 Received By (signature): Date/Time:

Relinquished By (signature): **Antony P. Stager** Date/Time:
 Relinquished By (signature): Date/Time:
 Relinquished By (signature): Date/Time:

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)



Instructions on back

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.: **25-02362**

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **NYS DOH**

Location: **INTERMEDIATE SCH.**

PO No.: **25-02362**

Send Invoice via: Mail Fax E-mail

Address: **← SAME**

City, State, Zip: **← SAME**

Contact: **← SAME**

Telephone No.: **← SAME**

Report Email: **← SAME**

Send Report via: Mail Fax E-mail

Project: **← SAME**

Sampled by (PRINT): **← SAME**

Sampler Signature: **← SAME**

Sampler Telephone No.: **← SAME**

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **← SAME**

Location: **← SAME**

PO No.: **← SAME**

Send Invoice via: Mail Fax E-mail

Address: **← SAME**

City, State, Zip: **← SAME**

Contact: **← SAME**

Telephone No.: **← SAME**

Report Email: **← SAME**

Send Report via: Mail Fax E-mail

Project: **← SAME**

Sampled by (PRINT): **← SAME**

Sampler Signature: **← SAME**

Sampler Telephone No.: **← SAME**

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **← SAME**

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Requested Analysis

Sample Disposition Dispose as appropriate Return Archive

Received By (signature)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Requested Analysis

Sample Disposition Dispose as appropriate Return Archive

Received By (signature)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Requested Analysis

Sample Disposition Dispose as appropriate Return Archive

Received By (signature)

CHAIN OF CUSTODY RECORD

3921 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.886.0169 (SAY)



Number Instructions on back

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

Project: **2025 COMPLIANCE**

Location: **INTERMEDIATE SCH.**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

PO No.: **25-02362**

Compliance Monitoring? Yes No

If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: **CRT HBG PTN SAY**

Holding Time:

Samples Received on Ice? **Yes No N/A**

Custody Seals Intact? **Yes No N/A**

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Disposal as appropriate: Dispose Return Archive

Received By (signature): *Antony P. Stager*

Date/Time: **11/14/25 12:45**

Relinquished By (signature):

Date/Time:

Additional Notes

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	319B	11/14/25	533	1	DW	Grab	I	LEAD IN DRINKING WATER
	317F	11/14/25	534	1	DW	Grab	I	
	317B	11/14/25	535	1	DW	Grab	I	
	324F	11/14/25	536	1	DW	Grab	I	
	324B	11/14/25	537	1	DW	Grab	I	
	322F	11/14/25	538	1	DW	Grab	I	

REQUESTED ANALYSIS

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive

Comments: **Drinking water samples lead in DW analysis Not preserved - to be preserved @ lab**

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC: Same as Above []
 Temperature Upon Receipt (°C):
 Thermometer ID: **CRT PTN**
 Samples Received on Ice? **Yes No N/A**

CHAIN OF CUSTODY RECORD

Number
Instructions on back


TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)



Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name:

Address: **← SAME**

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

INTERMEDIATE SCH.

PO No.: **25-02362**

Compliance Monitoring? Yes No
If Yes: Agency/Program: **NYSDOH**

Sampler Signature: **A.P. Stager**

Sampler Telephone No.:

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	322B	11/14/25	539	1	DW	Grab	1	LEAD IN DRINKING WATER
	A15F	11/14/25	540	1	DW	Grab	1	
	320F	11/14/25	541	1	DW	Grab	1	
	320B	11/14/25	542	1	DW	Grab	1	
	318F	11/14/25	543	1	DW	Grab	1	
	318B	11/14/25	544	1	DW	Grab	1	

Requested Analysis: **LEAD IN DRINKING WATER**

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive

Sample Disposition: Dispose as appropriate Return Archive

Relinquished By (signature): **Anthony P. Stager** Date/Time: **11/14/25 12:45**

Received By (signature): **J. Galluzzi** Date/Time: **11/14/25 12:45**

Relinquished By (signature): Date/Time:

Received By (signature): Date/Time:

*Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab*

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C): Same as Above
Thermometer ID: CRT PTN
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Lingiestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18840 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Compliance Monitoring? Yes No
 if Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location: **INTERMEDIATE SCH.**

PO No.: **25-02362**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	316F	11/14/25	545	1	DW	Grab	I	LEAD IN DRINKING WATER
	316B	11/14/25	546	1	DW	Grab	I	
	314F	11/14/25	547	1	DW	Grab	I	
	314B	11/14/25	548	1	DW	Grab	I	
	315A	11/14/25	549	1	DW	Grab	I	
	315B	11/14/25	550	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Received By (signature) *Palumy* Date/Time 11/14/25 1245
 Received By (signature) Date/Time

Relinquished By (signature) *Antony P. Stager*
 Relinquished By (signature)

Received By (signature) Date/Time

Relinquished By (signature) Date/Time

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN N/A
 Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)



Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Invoice Address

Client Name: HORSEHEADS CSD
 Address: 507 FLETCHER ST
 City, State, Zip: HORSEHEADS NY 14845
 Contact: TONY STAGER
 Telephone No.: 607-795-2592
 Report Email: astager@gstbores.org
 Send Report via: Mail Fax E-mail

Turnaround Time

Level 1 Level 2 Level 3 Level 4
 Results Only
 EDD

Project: 2025 COMPLIANCE Location: INTERMEDIATE SCH. PO No.: 25-02362 Compliance Monitoring? Yes No
 Agency/Program: NYS DOH
 Sampler Signature: A.P. Stager Sampler Telephone No.:
 * Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	313A	11/14/25	551	1	DW	Grab	I	LEAD IN DRINKING WATER
	313B	11/14/25	552	1	DW	Grab	I	
	FAC CON 2	11/14/25	553	1	DW	Grab	I	
	312F	11/14/25	554	1	DW	Grab	I	
	312B	11/14/25	555	1	DW	Grab	I	
	310F	11/14/25	556	1	DW	Grab	I	

Requested Analysis: Disposition as appropriate Return Archive

Received By (signature): *Anthony P. Stager* Date/Time: 11/14/25 1245
 Received By (signature): *Anthony P. Stager* Date/Time:
 Relinquished By (signature): *Anthony P. Stager* Date/Time:
 Relinquished By (signature): *Anthony P. Stager* Date/Time:
 Relinquished By (signature):
 Relinquished By (signature):

Comments:
 Drinking water samples
 Lead in DW analysis - to
 Not preserved - to
 be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number:
 Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
 Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

2310 Elmira St.
 Sayre, PA 18840
 570.888.0169 (SAY)

428 Route 315 Hwy
 Pittston, PA 18640
 570.348.0775 (PTN)

4359 Lingiestown Rd.
 Harrisburg, PA 17112
 717.651.9700 (HBG)

3821 Buck Dr.
 Cortland, NY 13045
 607.753.3403 (CRT)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Sampler Signature: *A.P. Stager*

PO No.: **25-02362**

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	310B	11/14/25	557	1	DW	Grab	I	LEAD IN DRINKING WATER
	308F	11/14/25	558	1	DW	Grab	I	
	308B	11/14/25	559	1	DW	Grab	I	
	306E	11/14/25	600	1	DW	Grab	I	
	306B	11/14/25	601	1	DW	Grab	I	
	304F	11/14/25	602	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Received By (signature)

Palumy
 11/14/25 1245

Date/Time

Relinquished By (signature)
 Antony P. Stager

Date/Time

Relinquished By (signature)
 Antony P. Stager

Comments:

Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Received By (signature)

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

Same as Above []

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)



Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Client Name: HORSEHEADS CSD

Address: 507 FLETCHER ST

City, State, Zip: HORSEHEADS NY 14845

Contact: TONY STAGER

Telephone No.: 607-795-2592

Report Email: astager@gstbores.org

Send Report via: Mail Fax E-mail

Project: 2025 COMPLIANCE

Location: INTERMEDIATE SCH.

PO No.: 25-02362

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

Project: 2025 COMPLIANCE

Sampler Signature: A.P. Stager

Sampler Telephone No.:

Compliance Monitoring? Yes No
If Yes: Agency/Program: NY S DOH

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

CHAIN OF CUSTODY RECORD

Number: 3821 Buck Dr.
 Instructions on back: 4359 Lingiestown Rd.
 TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time: 428 Route 315 Hwy
 Routine (7-10 bus. days) [X]
 RUSH* (notify lab) []

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Lab Report Address: 3821 Buck Dr. Cortland, NY 13045 607.753.3403 (CRT)
 Invoice Address: 4359 Lingiestown Rd. Harrisburg, PA 17112 717.651.9700 (HBG)
 Client Name: 428 Route 315 Hwy Pittston, PA 18640 570.348.0775 (PTN)
 Address: 570.888.0169 (SAY)

Project: 2025 COMPLIANCE Location: INTERMEDIATE SCH. PO No.: 25-02362 Compliance Monitoring? [X] Yes [] No
 Agency/Program: NYS DOH

Sampled by (PRINT): ANTONY P. STAGER Sampler Signature: A.P. Stager
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Report Type: [] Results Only [X]
 Level 1 [] Level 2 [] Level 3 [] Level 4 [] EDD

Send Report via: [] Mail [] Fax [X] E-mail

Report Email: astager@gstboxes.org Invoice Email:

Relinquished By (signature): Anthony P. Stager

Lab Report Address

Client Name

Address

City, State, Zip

Contact

Telephone No.

Report Email

Send Report via

Project

Sampled by (PRINT)

Matrix Types

Preservative Types

Report Type

Send Report via

Report Email

Relinquished By (signature)

CHAIN OF CUSTODY RECORD

Number: 2310 Elmira St.
 Instructions on back Sayre, PA 18840

3821 Buck Dr.
 Cortland, NY 13045
 607.753.3403 (CRT)

4359 Linglestown Rd.
 Harrisburg, PA 17112
 717.651.9700 (HBG)

428 Route 315 Hwy
 Pittston, PA 18640
 570.348.0775 (PTN)

570.888.0169 (SAY)

Lab Report Address

Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gstbores.org**
 Send Report via: Mail Fax E-mail

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name:
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Project:

2025 COMPLIANCE

Lab Report Address

Client Name:
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Report via: Mail Fax E-mail

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:
 Sampler Signature: **A.P. Stager**

PO No.: **25-02362**

Location: **INTERMEDIATE SCH.**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	303F	11/14/25	6:15	1	DW	Grab	I	LEAD IN DRINKING WATER
	303B	11/14/25	6:16	1	DW	Grab	I	
	301F	11/14/25	6:17	1	DW	Grab	I	
	301B	11/14/25	6:18	1	DW	Grab	I	
	MOF	11/14/25	6:19	1	DW	Grab	I	
	SOC1	11/14/25	6:20	1	DW	Grab	I	

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive

Sample Disposition: Dispose as appropriate Return Archive
 Relinquished By (signature): **Antony P. Stager**
 Relinquished By (signature):
 Relinquished By (signature):

Received By (signature): **[Signature]**
 Received By (signature):
 Received By (signature):

Date/Time: 11/14/25 12:45
 Date/Time:
 Date/Time:

Comments:
Drinking water samples
Lead in DW analysis
Not preserved - to be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Lingelstown Rd. 428 Route 315 Hwy 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)

Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
 Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

Results Only

Level 1 Level 2 Level 3 Level 4

EDD

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **NYSDOH**

Sampler Telephone No.:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Location:

INTERMEDIATE SCH.

PO No.: 25-02362

Sampler Signature: *A.P. Stager*

Sampled by (PRINT): **ANTONY P. STAGER**

- * Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
- ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Additional Notes
	SOC 2	11/14/25	621	1	DW	Grab	1	LEAD IN DRINKING WATER
	ISGYM F	11/14/25	622	1	DW	Grab	1	
	BOTG	11/14/25	623	1	DW	Grab	1	
	FNT 11	11/14/25	624	1	DW	Grab	1	
	ICE	11/14/25	625	1	DW	Grab	1	
		11/14/25		1	DW	Grab	1	

Sample Disposition Dispose as appropriate Return Archive

Received By (signature) *Galunz* Date/Time 11/14/25 12:45
 Received By (signature) _____ Date/Time _____

Date/Time _____
 Date/Time _____

Relinquished By (signature) *Antony P. Stager*
 Relinquished By (signature) _____

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C): Same as Above
 Thermometer ID: _____

Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbooces.org**

Send Report via: Mail Fax E-mail

Project: **2025 COMPLIANCE**

Comments:

*Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab*