



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Project Description

Middle School

For:

Michael Coghlan

Horseheads Central School District

507 Fletcher Street

Horseheads, NY 14845

Service Center Manager

Joseph Palanza

Wednesday, December 31, 2025

Please find enclosed the analytical results for the samples you submitted to Microbac Laboratories. Review and compilation of your report was completed by Microbac Laboratories, Inc., Sayre Division. If you have any questions, comments, or require further assistance regarding this report, please contact your service representative listed above.

I certify that all test results meet all of the requirements of the accrediting authority listed within this report. Analytical results are reported on a 'as received' basis unless specified otherwise. Analytical results for solids with units ending in (dry) are reported on a dry weight basis. A statement of uncertainty for each analysis is available upon request. This laboratory report shall not be reproduced, except in full, without the written approval of Microbac Laboratories. The reported results are related only to the samples analyzed as received.

Microbac Laboratories, Inc.

2310 Elmira Street | Sayre, PA 18840 | 570-888-0169 p | www.microbac.com



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Horseheads Central School District

Project Name: Middle School

Michael Coghlan
507 Fletcher Street
Horseheads, NY 14845

Project / PO Number: 25-02362
Received: 11/30/2025
Reported: 12/31/2025

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
LIB F	S5K0534-01	Drinking Water	Grab		11/14/25 06:30	11/30/25 21:41
BOT 7	S5K0534-02	Drinking Water	Grab		11/14/25 06:31	11/30/25 21:41
FNT 12	S5K0534-03	Drinking Water	Grab		11/14/25 06:32	11/30/25 21:41
MOFM	S5K0534-04	Drinking Water	Grab		11/14/25 06:33	11/30/25 21:41
N-1M	S5K0534-05	Drinking Water	Grab		11/14/25 06:34	11/30/25 21:41
N-2M	S5K0534-06	Drinking Water	Grab		11/14/25 06:35	11/30/25 21:41
BOT-8	S5K0534-07	Drinking Water	Grab		11/14/25 06:36	11/30/25 21:41
FNT 13	S5K0534-08	Drinking Water	Grab		11/14/25 06:37	11/30/25 21:41
BOT 10	S5K0534-09	Drinking Water	Grab		11/14/25 06:38	11/30/25 21:41
FNT 15	S5K0534-10	Drinking Water	Grab		11/14/25 06:39	11/30/25 21:41
FACF2	S5K0534-11	Drinking Water	Grab		11/14/25 06:40	11/30/25 21:41
221F	S5K0534-12	Drinking Water	Grab		11/14/25 06:41	11/30/25 21:41
214F	S5K0534-13	Drinking Water	Grab		11/14/25 06:42	11/30/25 21:41
216A	S5K0534-14	Drinking Water	Grab		11/14/25 06:43	11/30/25 21:41
216B	S5K0534-15	Drinking Water	Grab		11/14/25 06:44	11/30/25 21:41
216C	S5K0534-16	Drinking Water	Grab		11/14/25 06:45	11/30/25 21:41
216D	S5K0534-17	Drinking Water	Grab		11/14/25 06:46	11/30/25 21:41
216E	S5K0534-18	Drinking Water	Grab		11/14/25 06:47	11/30/25 21:41
216F	S5K0534-19	Drinking Water	Grab		11/14/25 06:48	11/30/25 21:41
FNT16	S5K0534-20	Drinking Water	Grab		11/14/25 06:49	11/30/25 21:41
BOT11	S5K0534-21	Drinking Water	Grab		11/14/25 06:50	11/30/25 21:41
BOT12	S5K0534-22	Drinking Water	Grab		11/14/25 06:51	11/30/25 21:41
FNT17	S5K0534-23	Drinking Water	Grab		11/14/25 06:52	11/30/25 21:41
FNT18	S5K0534-24	Drinking Water	Grab		11/14/25 06:53	11/30/25 21:41
FNT19	S5K0534-25	Drinking Water	Grab		11/14/25 06:54	11/30/25 21:41
BOT13	S5K0534-26	Drinking Water	Grab		11/14/25 06:55	11/30/25 21:41
CS-1A	S5K0534-27	Drinking Water	Grab		11/14/25 06:56	11/30/25 21:41
CS-1B	S5K0534-28	Drinking Water	Grab		11/14/25 06:57	11/30/25 21:41
118A	S5K0534-29	Drinking Water	Grab		11/14/25 06:58	11/30/25 21:41
118B	S5K0534-30	Drinking Water	Grab		11/14/25 06:59	11/30/25 21:41
116A	S5K0534-31	Drinking Water	Grab		11/14/25 07:00	11/30/25 21:41
116B	S5K0534-32	Drinking Water	Grab		11/14/25 07:01	11/30/25 21:41
FNT20	S5K0534-33	Drinking Water	Grab		11/14/25 07:02	11/30/25 21:41
BOT14	S5K0534-34	Drinking Water	Grab		11/14/25 07:03	11/30/25 21:41
FNT21	S5K0534-35	Drinking Water	Grab		11/14/25 07:04	11/30/25 21:41
FNT22	S5K0534-36	Drinking Water	Grab		11/14/25 07:05	11/30/25 21:41
BOT15	S5K0534-37	Drinking Water	Grab		11/14/25 07:06	11/30/25 21:41
129A	S5K0534-38	Drinking Water	Grab		11/14/25 07:07	11/30/25 21:41
129C	S5K0534-39	Drinking Water	Grab		11/14/25 07:08	11/30/25 21:41

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
129C	S5K0534-40	Drinking Water	Grab		11/14/25 07:09	11/30/25 21:41
127A	S5K0534-41	Drinking Water	Grab		11/14/25 07:10	11/30/25 21:41
127B	S5K0534-42	Drinking Water	Grab		11/14/25 07:11	11/30/25 21:41
BOT16	S5K0534-43	Drinking Water	Grab		11/14/25 07:12	11/30/25 21:41
FNT23	S5K0534-44	Drinking Water	Grab		11/14/25 07:13	11/30/25 21:41
FNT24	S5K0534-45	Drinking Water	Grab		11/14/25 07:14	11/30/25 21:41
106AF	S5K0534-46	Drinking Water	Grab		11/14/25 07:15	11/30/25 21:41
101F	S5K0534-47	Drinking Water	Grab		11/14/25 07:16	11/30/25 21:41
BOT17	S5K0534-48	Drinking Water	Grab		11/14/25 07:17	11/30/25 21:41
FNT25	S5K0534-49	Drinking Water	Grab		11/14/25 07:18	11/30/25 21:41
199F	S5K0534-50	Drinking Water	Grab		11/14/25 07:19	11/30/25 21:41
FAC-1F	S5K0534-51	Drinking Water	Grab		11/14/25 07:20	11/30/25 21:41



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Analytical Testing Parameters

Client Sample ID: LIB F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:30
Lab Sample ID: S5K0534-01	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00953	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1240	JXY

Client Sample ID: BOT 7	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:31
Lab Sample ID: S5K0534-02	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1245	JXY

Client Sample ID: FNT 12	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:32
Lab Sample ID: S5K0534-03	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1247	JXY

Client Sample ID: MOFM	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:33
Lab Sample ID: S5K0534-04	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00240	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1249	JXY

Client Sample ID: N-1M	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:34
Lab Sample ID: S5K0534-05	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00278	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1256	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: N-2M	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:35
Lab Sample ID: S5K0534-06	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00638	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1258	JXY

Client Sample ID: BOT-8	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:36
Lab Sample ID: S5K0534-07	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1300	JXY

Client Sample ID: FNT 13	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:37
Lab Sample ID: S5K0534-08	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1301	JXY

Client Sample ID: BOT 10	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:38
Lab Sample ID: S5K0534-09	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1303	JXY

Client Sample ID: FNT 15	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:39
Lab Sample ID: S5K0534-10	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1305	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: FACF2	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:40
Lab Sample ID: S5K0534-11	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00672	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1307	JXY

Client Sample ID: 221F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:41
Lab Sample ID: S5K0534-12	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00219	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1308	JXY

Client Sample ID: 214F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:42
Lab Sample ID: S5K0534-13	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00144	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1310	JXY

Client Sample ID: 216A	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:43
Lab Sample ID: S5K0534-14	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00139	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1312	JXY

Client Sample ID: 216B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:44
Lab Sample ID: S5K0534-15	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00130	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1319	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: 216C	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:45
Lab Sample ID: S5K0534-16	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00102	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1321	JXY

Client Sample ID: 216D	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:46
Lab Sample ID: S5K0534-17	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00176	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1322	JXY

Client Sample ID: 216E	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:47
Lab Sample ID: S5K0534-18	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00102	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1324	JXY

Client Sample ID: 216F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:48
Lab Sample ID: S5K0534-19	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00104	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1326	JXY

Client Sample ID: FNT16	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:49
Lab Sample ID: S5K0534-20	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1102	12/16/25 1327	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: BOT11	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:50
Lab Sample ID: S5K0534-21	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1341	JXY

Client Sample ID: BOT12	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:51
Lab Sample ID: S5K0534-22	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1347	JXY

Client Sample ID: FNT17	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:52
Lab Sample ID: S5K0534-23	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1348	JXY

Client Sample ID: FNT18	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:53
Lab Sample ID: S5K0534-24	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1350	JXY

Client Sample ID: FNT19	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:54
Lab Sample ID: S5K0534-25	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1352	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: BOT13	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:55
Lab Sample ID: S5K0534-26	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1353	JXY

Client Sample ID: CS-1A	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:56
Lab Sample ID: S5K0534-27	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1355	JXY

Client Sample ID: CS-1B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:57
Lab Sample ID: S5K0534-28	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00296	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1357	JXY

Client Sample ID: 118A	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:58
Lab Sample ID: S5K0534-29	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000849	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1404	JXY

Client Sample ID: 118B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 6:59
Lab Sample ID: S5K0534-30	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000660	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1406	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: 116A	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0534-31		Collection Date: 11/14/2025 7:00

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1407	JXY

Client Sample ID: 116B	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0534-32		Collection Date: 11/14/2025 7:01

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000829	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1409	JXY

Client Sample ID: FNT20	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0534-33		Collection Date: 11/14/2025 7:02

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00133	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1411	JXY

Client Sample ID: BOT14	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0534-34		Collection Date: 11/14/2025 7:03

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00162	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1413	JXY

Client Sample ID: FNT21	Sample Matrix: Drinking Water	Collected By: Antony P Stager
Lab Sample ID: S5K0534-35		Collection Date: 11/14/2025 7:04

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1414	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: FNT22	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:05
Lab Sample ID: S5K0534-36	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1416	JXY

Client Sample ID: BOT15	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:06
Lab Sample ID: S5K0534-37	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1418	JXY

Client Sample ID: 129A	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:07
Lab Sample ID: S5K0534-38	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1420	JXY

Client Sample ID: 129C	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:08
Lab Sample ID: S5K0534-39	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1430	JXY

Client Sample ID: 129C	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:09
Lab Sample ID: S5K0534-40	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1104	12/16/25 1432	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: 127A	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:10
Lab Sample ID: S5K0534-41	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1442	JXY

Client Sample ID: 127B	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:11
Lab Sample ID: S5K0534-42	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1448	JXY

Client Sample ID: BOT16	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:12
Lab Sample ID: S5K0534-43	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1458	JXY

Client Sample ID: FNT23	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:13
Lab Sample ID: S5K0534-44	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1500	JXY

Client Sample ID: FNT24	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:14
Lab Sample ID: S5K0534-45	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00189	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1502	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: 106AF	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:15
Lab Sample ID: S5K0534-46	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00235	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1503	JXY

Client Sample ID: 101F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:16
Lab Sample ID: S5K0534-47	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00148	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1505	JXY

Client Sample ID: BOT17	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:17
Lab Sample ID: S5K0534-48	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1507	JXY

Client Sample ID: FNT25	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:18
Lab Sample ID: S5K0534-49	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1509	JXY

Client Sample ID: 199F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:19
Lab Sample ID: S5K0534-50	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00162	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1510	JXY



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5K0534

Client Sample ID: FAC-1F	Collected By: Antony P Stager
Sample Matrix: Drinking Water	Collection Date: 11/14/2025 7:20
Lab Sample ID: S5K0534-51	

Analyses Performed by: Microbac Laboratories, Inc., Pittston Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000782	0.00500 AL	0.000400	mg/L		12/16/25 1105	12/16/25 1512	JXY

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	Yes
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	Yes
VOA vials have zero headspace, or not recd.?	Yes		

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Joseph Palanza
Service Center Manager
Reported: 12/31/2025 18:48

CHAIN OF CUSTODY RECORD

3821 Buck Dr. 4359 Linglestown Rd. 428 Route 315 Hwy. 2310 Elmira St.
 Cortland, NY 13045 Harrisburg, PA 17112 Pittston, PA 18640 Sayre, PA 18840
 607.753.3403 (CRT) 717.651.9700 (HBG) 570.348.0775 (PTN) 570.888.0169 (SAY)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time:
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Report Type:
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Invoice Address:
 Client Name:
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Lab Report Address:
 Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gstboce.org**
 Send Report via: Mail Fax E-mail

Compliance Monitoring? Yes No
 If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:
 PO No.: **25-02362**

Location: **MIDDLE SCHOOL**
 Sampler Signature: **A. Stager**

Sampled by (PRINT): **ANTONY P. STAGER**
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
 PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Addit
	LIRF	11/14/25	630	1	DW	Grab	I	LEAD IN DRINKING WATER	
	BOT7	11/14/25	631	1	DW	Grab	I		
	FNT12	11/14/25	632	1	DW	Grab	I		
	M0FM	11/14/25	633	1	DW	Grab	I		
	N-1M	11/14/25	634	1	DW	Grab	I		
	N-2M	11/14/25	635	1	DW	Grab	I		

Possible Hazard Identification: Hazardous Non-Hazardous
 Sample Disposition: Dispose as appropriate Return Archive
 Relinquished By (signature): **Antony P. Stager**
 Relinquished By (signature):
 Relinquished By (signature):
 Relinquished By (signature):

Comments:
Drinking water samples lead in DW analysis - to Not preserved - to be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C): Same as Above
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Lingiestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Invoice Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

← SAME

Project: **2025 COMPLIANCE** Location: **MIDDLE SCHOOL** PO No.: **25-02362** Compliance Monitoring? Yes No
Agency/Program: **NYS**

Sampled by (PRINT): **ANTONY P. STAGER** Sampler Signature: *Antony P. Stager* Sampler Telephone No.:

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (sp)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis
	BOT-8	11/14/25	636	1	DW	Grab	1	LEAD IN DRINKING WATER
	FNT13	11/14/25	637	1	DW	Grab	1	
	BOT10	11/14/25	638	1	DW	Grab	1	
	FNT15	11/14/25	639	1	DW	Grab	1	
	FACF2	11/14/25	640	1	DW	Grab	1	
	201F	11/14/25	641	1	DW	Grab	1	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Relinquished By (signature): *Antony P. Stager*
Relinquished By (signature):
Relinquished By (signature):

Sample Disposition Dispose as appropriate Return Archive

Date/Time Received By (signature):
Date/Time Received By (signature):
Date/Time Received By (signature):

Comments:
**Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab**

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C): Same as Above
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back


TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18640
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)



Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gstbores.org**

Send Report via: Mail Fax E-mail

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Send Invoice via: Mail Fax E-mail

Project: **2025 COMPLIANCE**

Location: **MIDDLE SCHOOL**

PO No.: **25-02362**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

- * Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other
- ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis
	214 F	11/14/25	642	1	DW	Grab	1	LEAD IN DRINKING WATER
	216 A	11/14/25	643	1	DW	Grab	1	
	216 B	11/14/25	644	1	DW	Grab	1	
	216 C	11/14/25	645	1	DW	Grab	1	
	216 D	11/14/25	646	1	DW	Grab	1	
	216 E	11/14/25	647	1	DW	Grab	1	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Relinquished By (signature) *Antony P. Stager*

Relinquished By (signature)

Comments:
Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back


TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)



Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Report Type
 Results Only
[] Level 1 [] Level 2 [] Level 3 [] Level 4
[] EDD

Invoice Address
Client Name:
Address:
City, State, Zip:
Contact:
Telephone No.:

← SAME

Lab Report Address
Client Name: HORSEHEADS CSD
Address: 509 FLETCHER ST
City, State, Zip: HORSEHEADS NY 14845
Contact: TONY STAGER
Telephone No.: 607-795-2592
Report Email: astager@gstoboces.org
Send Report via: [] Mail [] Fax E-mail

Invoice Address
Client Name:
Address:
City, State, Zip:
Contact:
Telephone No.:

← SAME

Lab Report Address
Client Name: HORSEHEADS CSD
Address: 509 FLETCHER ST
City, State, Zip: HORSEHEADS NY 14845
Contact: TONY STAGER
Telephone No.: 607-795-2592
Report Email: astager@gstoboces.org
Send Report via: [] Mail [] Fax E-mail

Compliance Monitoring? Yes [] No
Agency/Program: NYS DOH

Sampler Telephone No.:
PO No.: 25-02362

Location: MIDDLE SCHOOL
Sampler Signature: A.P. Stager

Project: 2025 COMPLIANCE
Sampled by (PRINT): ANTONY P. STAGER

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (sp)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Meihano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

No. of Containers
Matrix *

Date Collected
Time Collected

Client Sample ID
Date/Time



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Sample Disposition	Date/Time	Received By (signature)	Date/Time
	216 F	11/14/25	648	1	DW	Grab	1	Disposal as appropriate <input checked="" type="checkbox"/> Return <input type="checkbox"/> Arc			
	FNT16	11/14/25	649	1	DW	Grab	1				
	BOT11	11/14/25	650	1	DW	Grab	1				
	BOT12	11/14/25	651	1	DW	Grab	1				
	FNT17	11/14/25	652	1	DW	Grab	1				
	FNT18	11/14/25	653	1	DW	Grab	1				

Requested Analysis: LEAD IN DRINKING WATER

Relinquished By (signature): Anthony P. Stager
Relinquished By (signature): Anthony P. Stager

Comments:
Drinking water samples
Lead in DW analysis
Not preserved - to be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C): Same as Above []
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.886.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)



Turnaround Time
 Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Invoice Address
 Client Name:
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:
 Invoice Email:
 Send Invoice via: Mail Fax E-mail

Project: 2025 COMPLIANCE
 Location: MIDDLE SCHOOL
 PO No.: 25-02362
 Compliance Monitoring? Yes No
 Agency/Program: NYS DWS

Sampled by (PRINT): ANTONY P. STAGER
 Sampler Signature: *Anthony P. Stager*
 Sampler Telephone No.:

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (spec)
 ** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
 PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis
	FNT 19	11/14/25	654	1	DW	Grab	I	LEAD IN DRINKING WATER
	BOT 13	11/14/25	655	1	DW	Grab	I	
	CS-1A	11/14/25	656	1	DW	Grab	I	
	CS-1B	11/14/25	657	1	DW	Grab	I	
	118A	11/14/25	658	1	DW	Grab	I	
	118B	11/14/25	659	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature): *Anthony P. Stager*

Relinquished By (signature):

Relinquished By (signature):

Relinquished By (signature):

Comments:
 Drinking water samples
 Lead in DW analysis
 Not preserved - to be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C): Same as Above
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

MICROBAC

Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Invoice Address

Client Name:

Address: **← SAME**

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: Mail Fax E-mail

Lab Report Address

Client Name:

Address: **HORSEHEADS CSD**

City, State, Zip:

Contact:

Telephone No.:

Report Email:

Send Report via: Mail Fax E-mail

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Compliance Monitoring? Yes No
If Yes: Agency/Program: **MYS Now**

Sampler Telephone No.:

Project: **2025 COMPLIANCE** Location: **MIDDLE SCHOOL** PO No.: **25-02362**

Sampled by (PRINT): **ANTONY P. STAGER** Sampler Signature: *Antony P. Stager*

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (spe)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methano(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis
	116A	11/14/25	7:00	1	DW	Grab	I	LEAD IN DRINKING WATER
	116B	11/14/25	7:01	1	DW	Grab	I	
	FNT 20	11/14/25	7:02	1	DW	Grab	I	
	BOT 14	11/14/25	7:03	1	DW	Grab	I	
	FNT 21	11/14/25	7:04	1	DW	Grab	I	
	FNT 22	11/14/25	7:05	1	DW	Grab	I	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature) *Antony P. Stager* Received By (signature)

Relinquished By (signature) Relinquished By (signature)

*Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab*

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C): Same as Above []
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number: 2310 Elmira St.
 Instructions on back: Sayre, PA 18840
 TO BE COMPLETED BY INITIAL RECEIVING MICROBAC: 570.888.0169 (SAY)

428 Route 315 Hwy
 Harrisburg, PA 17112
 570.348.0775 (PTN)

4359 Linglestown Rd.
 Harrisburg, PA 17112
 717.651.9700 (HBG)

3821 Buck Dr.
 Cortland, NY 13045
 607.753.3403 (CRT)



Turnaround Time

Routine (7-10 bus. days)
 RUSH* (notify lab)

Invoice Address

Client Name: **← SAME**
 Address: **← SAME**
 City, State, Zip:

Lab Report Address

Client Name: **HORSEHEADS CSD**
 Address: **507 FLETCHER ST**
 City, State, Zip: **HORSEHEADS NY 14845**
 Contact: **TONY STAGER**
 Telephone No.: **607-795-2592**
 Report Email: **astager@gstobces.org**

Temperature Upon Receipt (°C):
 Thermometer ID:
 Receiving Lab: CRT HBG PTN SAY
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Report Type

Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Send Invoice via: Mail Fax E-mail

PO No.: **25-02362** Compliance Monitoring? Yes No
 Agency/Program: **NYS D**

Sampler Telephone No.:

Sampler Signature: **A.P. Stager**
 Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (Specify)
 Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (Specify)

Location:

MIDDLE SCHOOL
A.P. Stager

Sampled by (PRINT): **ANTONY P. STAGER**



Horseheads Central School District
 PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis
	BOT 15	11/14/25	706	1	DW	Grab	1	LEAD IN DRINKING WATER
	129A	11/14/25	707	1	DW	Grab	1	
	129B	11/14/25	708	1	DW	Grab	1	
	129C	11/14/25	709	1	DW	Grab	1	
	127A	11/14/25	710	1	DW	Grab	1	
	127B	11/14/25	711	1	DW	Grab	1	

Sample Disposition Dispose as appropriate Return Archive

Date/Time Received By (signature)
 Date/Time Received By (signature)
 Date/Time Received By (signature)

Reinquired By (signature)
 Reinquired By (signature)
 Reinquired By (signature)

Comments:

**Drinking water samples
 Lead in DW analysis
 Not preserved - to
 be preserved @ lab**

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
 Temperature Upon Receipt (°C): Same as Above
 Thermometer ID:
 Receiving Lab: CRT PTN
 Samples Received on Ice? Yes No N/A

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Sayre, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18640
570.886.0169 (SAY)

Lab Report Address

Invoice Address

Turnaround Time

Client Name: HORSEHEADS CSD
Address: 509 FLETCHER ST
City, State, Zip: HORSEHEADS NY 14845
Contact: TONY STAGER
Telephone No.: 607-795-2592
Report Email: astager@gstboxes.org
Send Report via: Mail Fax E-mail

Routine (7-10 bus. days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Report Type
 Results Only
 Level 1 Level 2 Level 3 Level 4
 EDD

Compliance Monitoring? Yes No
If Yes: Agency/Program: NYS DOH

Sampler Telephone No.:

Lab Report Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Report Email:

Send Report via:

Project:

Sampled by (PRINT):

Sampler Signature:

Location:

PO No.:

Matrix Types:

Preservative Types:



Horseheads Central School District
PM: Joseph Palanza

MIDDLE SCHOOL

ANTONY P. STAGER

2025 COMPLIANCE

25-02362

Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Additional
	FNT 25	11/14/25	718	1	DW	Grab	1	LEAD IN DRINKING WATER	
	199F	11/14/25	719	1	DW	Grab	1		
	FAC-1F	11/14/25	730	1	DW	Grab	1		
		11/14/25		1	DW	Grab	1		
		11/14/25		1	DW	Grab	1		
		11/14/25		1	DW	Grab	1		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Relinquished By (signature) *Antony P. Stager*

Relinquished By (signature)

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No N/A