



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Project Description

Big Flats Elem.

For:

Antony P Stager

Horseheads Central School District

143 Hibbard Road

Horseheads, NY 14845

Customer Relationship Specialist

Renee Lantz

Monday, June 30, 2025

Please find enclosed the analytical results for the samples you submitted to Microbac Laboratories. Review and compilation of your report was completed by Microbac Laboratories, Inc., Sayre Division. If you have any questions, comments, or require further assistance regarding this report, please contact your service representative listed above.

I certify that all test results meet all of the requirements of the accrediting authority listed within this report. Analytical results are reported on a 'as received' basis unless specified otherwise. Analytical results for solids with units ending in (dry) are reported on a dry weight basis. A statement of uncertainty for each analysis is available upon request. This laboratory report shall not be reproduced, except in full, without the written approval of Microbac Laboratories. The reported results are related only to the samples analyzed as received.

Microbac Laboratories, Inc.

2310 Elmira Street | Sayre, PA 18840 | 570-888-0169 p | www.microbac.com



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Horseheads Central School District

Project Name: Big Flats Elem.

Antony P Stager
143 Hibbard Road
Horseheads, NY 14845

Project / PO Number: N/A
Received: 06/06/2025
Reported: 06/30/2025

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
K-1	S5F0277-01	Drinking Water	Grab		06/06/25 04:45	06/06/25 11:50
K-2	S5F0277-02	Drinking Water	Grab		06/06/25 04:46	06/06/25 11:50
K-3	S5F0277-03	Drinking Water	Grab		06/06/25 04:47	06/06/25 11:50
K-4	S5F0277-04	Drinking Water	Grab		06/06/25 04:48	06/06/25 11:50
K-5	S5F0277-05	Drinking Water	Grab		06/06/25 04:49	06/06/25 11:50
STE-1	S5F0277-06	Drinking Water	Grab		06/06/25 04:50	06/06/25 11:50
301	S5F0277-07	Drinking Water	Grab		06/06/25 04:53	06/06/25 11:50
302	S5F0277-08	Drinking Water	Grab		06/06/25 04:54	06/06/25 11:50
305	S5F0277-09	Drinking Water	Grab		06/06/25 04:55	06/06/25 11:50
304	S5F0277-10	Drinking Water	Grab		06/06/25 04:56	06/06/25 11:50
306	S5F0277-11	Drinking Water	Grab		06/06/25 04:57	06/06/25 11:50
311	S5F0277-12	Drinking Water	Grab		06/06/25 04:58	06/06/25 11:50
308	S5F0277-13	Drinking Water	Grab		06/06/25 04:59	06/06/25 11:50
313	S5F0277-14	Drinking Water	Grab		06/06/25 05:00	06/06/25 11:50
310	S5F0277-15	Drinking Water	Grab		06/06/25 05:01	06/06/25 11:50
315	S5F0277-16	Drinking Water	Grab		06/06/25 05:02	06/06/25 11:50
312	S5F0277-17	Drinking Water	Grab		06/06/25 05:03	06/06/25 11:50
K-2A	S5F0277-18	Drinking Water	Grab		06/06/25 04:51	06/06/25 11:50
K-3A	S5F0277-19	Drinking Water	Grab		06/06/25 04:52	06/06/25 11:50
BOT-3	S5F0277-20	Drinking Water	Grab		06/06/25 05:04	06/06/25 11:50
FNT-3	S5F0277-21	Drinking Water	Grab		06/06/25 05:05	06/06/25 11:50
400A	S5F0277-22	Drinking Water	Grab		06/06/25 05:06	06/06/25 11:50
400B	S5F0277-23	Drinking Water	Grab		06/06/25 05:07	06/06/25 11:50
402A	S5F0277-24	Drinking Water	Grab		06/06/25 05:08	06/06/25 11:50
402B	S5F0277-25	Drinking Water	Grab		06/06/25 05:09	06/06/25 11:50
404A	S5F0277-26	Drinking Water	Grab		06/06/25 05:10	06/06/25 11:50
404B	S5F0277-27	Drinking Water	Grab		06/06/25 05:11	06/06/25 11:50
412A	S5F0277-28	Drinking Water	Grab		06/06/25 05:12	06/06/25 11:50
412B	S5F0277-29	Drinking Water	Grab		06/06/25 05:13	06/06/25 11:50
410A	S5F0277-30	Drinking Water	Grab		06/06/25 05:14	06/06/25 11:50
410B	S5F0277-31	Drinking Water	Grab		06/06/25 05:15	06/06/25 11:50
BOT GYM	S5F0277-32	Drinking Water	Grab		06/06/25 05:17	06/06/25 11:50
F GYM 1	S5F0277-33	Drinking Water	Grab		06/06/25 05:18	06/06/25 11:50
F GYM 2	S5F0277-34	Drinking Water	Grab		06/06/25 05:19	06/06/25 11:50
401A	S5F0277-35	Drinking Water	Grab		06/06/25 05:21	06/06/25 11:50
401B	S5F0277-36	Drinking Water	Grab		06/06/25 05:22	06/06/25 11:50

ART A	S5F0277-37	Drinking Water	Grab	06/06/25 05:30	06/06/25 11:50
ART B	S5F0277-38	Drinking Water	Grab	06/06/25 05:31	06/06/25 11:50
ART C	S5F0277-39	Drinking Water	Grab	06/06/25 05:32	06/06/25 11:50
203A	S5F0277-40	Drinking Water	Grab	06/06/25 05:33	06/06/25 11:50
203B	S5F0277-41	Drinking Water	Grab	06/06/25 05:34	06/06/25 11:50
205A	S5F0277-42	Drinking Water	Grab	06/06/25 05:35	06/06/25 11:50
205B	S5F0277-43	Drinking Water	Grab	06/06/25 05:36	06/06/25 11:50
204A	S5F0277-44	Drinking Water	Grab	06/06/25 05:37	06/06/25 11:50
204B	S5F0277-45	Drinking Water	Grab	06/06/25 05:38	06/06/25 11:50
207A	S5F0277-46	Drinking Water	Grab	06/06/25 05:39	06/06/25 11:50
207B	S5F0277-47	Drinking Water	Grab	06/06/25 05:40	06/06/25 11:50
206A	S5F0277-48	Drinking Water	Grab	06/06/25 05:41	06/06/25 11:50
206B	S5F0277-49	Drinking Water	Grab	06/06/25 05:42	06/06/25 11:50
209A	S5F0277-50	Drinking Water	Grab	06/06/25 05:43	06/06/25 11:50
209B	S5F0277-51	Drinking Water	Grab	06/06/25 05:44	06/06/25 11:50
208A	S5F0277-52	Drinking Water	Grab	06/06/25 05:45	06/06/25 11:50
208B	S5F0277-53	Drinking Water	Grab	06/06/25 05:46	06/06/25 11:50
211A	S5F0277-54	Drinking Water	Grab	06/06/25 05:47	06/06/25 11:50
211B	S5F0277-55	Drinking Water	Grab	06/06/25 05:48	06/06/25 11:50
210A	S5F0277-56	Drinking Water	Grab	06/06/25 05:49	06/06/25 11:50
210B	S5F0277-57	Drinking Water	Grab	06/06/25 05:50	06/06/25 11:50
BOT 2	S5F0277-58	Drinking Water	Grab	06/06/25 05:51	06/06/25 11:50
FNT 2	S5F0277-59	Drinking Water	Grab	06/06/25 05:52	06/06/25 11:50
BOT CAFE	S5F0277-60	Drinking Water	Grab	06/06/25 05:53	06/06/25 11:50
FNT CAFE 1	S5F0277-61	Drinking Water	Grab	06/06/25 05:54	06/06/25 11:50
FNT CAFE 2	S5F0277-62	Drinking Water	Grab	06/06/25 05:55	06/06/25 11:50
MAIL F	S5F0277-63	Drinking Water	Grab	06/06/25 05:57	06/06/25 11:50
CON F	S5F0277-64	Drinking Water	Grab	06/06/25 05:58	06/06/25 11:50
BOT 1	S5F0277-65	Drinking Water	Grab	06/06/25 05:59	06/06/25 11:50
FNT 1	S5F0277-66	Drinking Water	Grab	06/06/25 06:00	06/06/25 11:50
NUR 1	S5F0277-67	Drinking Water	Grab	06/06/25 06:02	06/06/25 11:50
NUR 2	S5F0277-68	Drinking Water	Grab	06/06/25 06:03	06/06/25 11:50
101A	S5F0277-69	Drinking Water	Grab	06/06/25 06:04	06/06/25 11:50
101B	S5F0277-70	Drinking Water	Grab	06/06/25 06:05	06/06/25 11:50
100A	S5F0277-71	Drinking Water	Grab	06/06/25 06:06	06/06/25 11:50
100B	S5F0277-72	Drinking Water	Grab	06/06/25 06:07	06/06/25 11:50
103A	S5F0277-73	Drinking Water	Grab	06/06/25 06:09	06/06/25 11:50
103B	S5F0277-74	Drinking Water	Grab	06/06/25 06:10	06/06/25 11:50

102A	S5F0277-75	Drinking Water	Grab	06/06/25 06:11	06/06/25 11:50
102B	S5F0277-76	Drinking Water	Grab	06/06/25 06:12	06/06/25 11:50
105A	S5F0277-77	Drinking Water	Grab	06/06/25 06:13	06/06/25 11:50
105B	S5F0277-78	Drinking Water	Grab	06/06/25 06:14	06/06/25 11:50
104A	S5F0277-79	Drinking Water	Grab	06/06/25 06:15	06/06/25 11:50
104B	S5F0277-80	Drinking Water	Grab	06/06/25 06:16	06/06/25 11:50
BOT 4	S5F0277-81	Drinking Water	Grab	06/06/25 06:20	06/06/25 11:50
FNT 4	S5F0277-82	Drinking Water	Grab	06/06/25 06:21	06/06/25 11:50
FNT 5	S5F0277-83	Drinking Water	Grab	06/06/25 06:22	06/06/25 11:50



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Analytical Testing Parameters

Client Sample ID: K-1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-01
Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1716	DLO

Client Sample ID: K-2
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-02
Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1720	DLO

Client Sample ID: K-3
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-03
Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1721	DLO

Client Sample ID: K-4
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-04
Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1723	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: K-5
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-05

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1725	DLO

Client Sample ID: STE-1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-06

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1726	DLO

Client Sample ID: 301
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-07

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0076	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1731	DLO

Client Sample ID: 302
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-08

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0066	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1732	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 305
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-09

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0301	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1734	DLO

Client Sample ID: 304
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-10

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0471	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1735	DLO

Client Sample ID: 306
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-11

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0075	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1737	DLO

Client Sample ID: 311
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-12

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1740	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 308
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-13

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0071	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1741	DLO

Client Sample ID: 313
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-14

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1743	DLO

Client Sample ID: 310
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-15

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0139	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1744	DLO

Client Sample ID: 315
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-16

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1749	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 312
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-17

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1750	DLO

Client Sample ID: K-2A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-18

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1752	DLO

Client Sample ID: K-3A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-19

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 4:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1754	DLO

Client Sample ID: BOT-3
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-20

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1755	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: FNT-3
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-21

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1803	DLO

Client Sample ID: 400A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-22

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1807	DLO

Client Sample ID: 400B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-23

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1809	DLO

Client Sample ID: 402A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-24

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1810	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 402B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-25

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1812	DLO

Client Sample ID: 404A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-26

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1814	DLO

Client Sample ID: 404B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-27

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1818	DLO

Client Sample ID: 412A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-28

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1820	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 412B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-29

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1821	DLO

Client Sample ID: 410A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-30

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1823	DLO

Client Sample ID: 410B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-31

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1824	DLO

Client Sample ID: BOT GYM
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-32

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1827	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: F GYM 1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-33

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1829	DLO

Client Sample ID: F GYM 2
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-34

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1830	DLO

Client Sample ID: 401A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-35

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1832	DLO

Client Sample ID: 401B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-36

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:22

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1344	06/12/25 1836	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: ART A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-37

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1838	DLO

Client Sample ID: ART B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-38

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1839	DLO

Client Sample ID: ART C
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-39

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1841	DLO

Client Sample ID: 203A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-40

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.0050 AL	0.0010	mg/L		06/12/25 1344	06/12/25 1843	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 203B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-41

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1850	DLO

Client Sample ID: 205A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-42

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1855	DLO

Client Sample ID: 205B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-43

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1856	DLO

Client Sample ID: 204A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-44

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0652	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1858	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 204B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-45

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1859	DLO

Client Sample ID: 207A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-46

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0111	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1901	DLO

Client Sample ID: 207B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-47

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/16/25 1456	DLO

Client Sample ID: 206A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-48

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1907	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 206B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-49

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1909	DLO

Client Sample ID: 209A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-50

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1910	DLO

Client Sample ID: 209B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-51

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0081	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1912	DLO

Client Sample ID: 208A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-52

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1915	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 208B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-53

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1916	DLO

Client Sample ID: 211A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-54

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1918	DLO

Client Sample ID: 211B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-55

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1919	DLO

Client Sample ID: 210A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-56

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1924	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 210B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-57

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1926	DLO

Client Sample ID: BOT 2
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-58

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1927	DLO

Client Sample ID: FNT 2
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-59

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1929	DLO

Client Sample ID: BOT CAFE
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-60

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1930	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: FNT CAFE 1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-61

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1938	DLO

Client Sample ID: FNT CAFE 2
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-62

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1942	DLO

Client Sample ID: MAIL F
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-63

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1944	DLO

Client Sample ID: CON F
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-64

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.369	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1946	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: BOT 1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-65

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 5:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1947	DLO

Client Sample ID: FNT 1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-66

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1949	DLO

Client Sample ID: NUR 1
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-67

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1953	DLO

Client Sample ID: NUR 2
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-68

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1955	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 101A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-69

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 1956	DLO

Client Sample ID: 101B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-70

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 1958	DLO

Client Sample ID: 100A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-71

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 2000	DLO

Client Sample ID: 100B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-72

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 2002	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 103A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-73

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0060	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 2004	DLO

Client Sample ID: 103B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-74

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 2006	DLO

Client Sample ID: 102A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-75

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 2007	DLO

Client Sample ID: 102B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-76

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 2012	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: 105A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-77

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 2013	DLO

Client Sample ID: 105B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-78

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L	J	06/12/25 1345	06/12/25 2015	DLO

Client Sample ID: 104A
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-79

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 2017	DLO

Client Sample ID: 104B
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-80

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/12/25 1345	06/12/25 2018	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Client Sample ID: BOT 4
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-81

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/11/25 1640	06/11/25 1854	DLO

Client Sample ID: FNT 4
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-82

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/11/25 1640	06/11/25 1856	DLO

Client Sample ID: FNT 5
Sample Matrix: Drinking Water
Lab Sample ID: S5F0277-83

Collected By: Anthony P. Stager
Collection Date: 06/06/2025 6:22

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		06/11/25 1640	06/11/25 1857	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level
J: Estimated value. The analyte concentration is less than the reporting/quantitation limit.
MDL: Minimum Detection Limit
mg/L: Milligrams per Liter
RL: Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5F0277

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	Yes
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	Yes
VOA vials have zero headspace, or not recd.?	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health


Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

Renee Lantz
Customer Relationship Specialist
Reported: 06/30/2025 17:13



3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoes.org**

Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Location: **BIG FLATS ELEM.**

Sampler Signature: *Antony P. Stager*

PO No.: **25-02362** Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:



Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	REQUESTED ANALYSIS	
									Addit
	K-1	6/6/25	445	1	DW	Grab	1	LEAD IN DRINKING WATER	
	K-2	6/6/25	446	1	DW	Grab	1		
	K-3	6/6/25	447	1	DW	Grab	1		
	K-4	6/6/25	448	1	DW	Grab	1		
	K-5	6/6/25	449	1	DW	Grab	1		
	STE-1	6/6/25	450	1	DW	Grab	1		

Possible Hazard Identification

☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)
Antony P. Stager

Date/Time
6/6/25 11:50

Received By (signature)
Joseph Palanza

Date/Time
6/6/25 11:50

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:


Temperature Upon Receipt (°C):

Thermometer ID:

Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Same as Above ☐



3921 Buck Dr.
Corland, NY 13045
607.753.3403 (CRT)

4359 Lingletown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.988.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14843**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoes.org**

Send Report via: ☐ Mail ☒ Fax ☒ E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Location:

Sampler Signature:

PO No.:

BIG FLATS ELEM.

25-02362

Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: **CRT HBG PTN SAY**

Holding Time:

Samples Received on Ice? Yes ☐ No ☒

Custody Seals Intact? Yes ☐ No ☒

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD



Horseheads Central School District

PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	LEAD IN DRINKING WATER	Requested Analysis	Addit
	301	6/6/25	453	1	DW	Grab	1	X		
	302	6/6/25	454	1	DW	Grab	1	X		
	305	6/6/25	455	1	DW	Grab	1	X		
	304	6/6/25	456	1	DW	Grab	1	X		
	306	6/6/25	457	1	DW	Grab	1	X		
	311	6/6/25	458	1	DW	Grab	1	X		

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature) **Antony P. Stager**

Date/Time **6/6/25 11:50**

Received By (signature) **Joseph Palanza**

Date/Time **6/6/2025 11:50**

Comments:

Drinking water samples
lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):


Thermometer ID:

Receiving Lab: **CRT PTN**

Samples Received on Ice? Yes ☐ No ☒

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Same as Above ☐



3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Location:

BIG FLATS ELEM.

PO No.: **25-02362**

Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreation Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



Horseheads Central School District

PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Requested Analysis	Addl
308		6/6/25	459	1	DW	Grab	1	LEAD IN DRINKING WATER	
313		6/6/25	500	1	DW	Grab	1		
310		6/6/25	501	1	DW	Grab	1		
315		6/6/25	502	1	DW	Grab	1		
312		6/6/25	503	1	DW	Grab	1		
K-24		6/6/25	451	1	DW	Grab	1		

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature) *Antony P. Stager*

Date/Time **6/6/25 1150**

Received By (signature) *J. Palanza*

Date/Time **6/6/25 1150**

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Same as Above ☐



3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time
☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Lab Report Address
Client Name: **HORSEHEADS CSD**
Address: **507 FLETCHER ST**
City, State, Zip: **HORSEHEADS NY 14845**
Contact: **TONY STAGER**
Telephone No.: **607-795-2592**
Report Email: **astager@gsthoes.org**
Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN
Holding Time: **SAY**

Samples Received on Ice? Yes No **N/A**

Custody Seals Intact? Yes No **N/A**

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

PO No.: **25-02362**

Sampler Telephone No.:

Sampler Signature: **Anthony P. Stager**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreation Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	LEAD IN DRINKING WATER	Additional
	K-3A	6/6/25	452	1	DW	Grab	1	X	
	BOT-3	6/6/25	504	1	DW	Grab	1	X	
	FNT-3	6/6/25	505	1	DW	Grab	1	X	
	400A	6/6/25	506	1	DW	Grab	1	X	
	400B	6/6/25	507	1	DW	Grab	1	X	
	402A	6/6/25	508	1	DW	Grab	1	X	

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Received By (signature)

Date/Time

Relinquished By (signature)

Relinquished By (signature)

Comments:
Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time


Date/Time

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:
Temperature Upon Receipt (°C):
Thermometer ID:
Receiving Lab: CRT PTN
Samples Received on Ice? Yes No **N/A**

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Page 31 of 41



3021 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Lingletown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreation Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

PO No.: **25-02362** Compliance Monitoring? ☒ Yes ☐ No

If Yes: Agency/Program: **NYS DOH**

Requested Analysis

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Sample Disposition	Archive
402B	6/6/25	509	1	DW	Grab	1	LEAD IN DRINKING WATER	☒ Dispose as appropriate ☐ Return ☐ Archive	
404A	6/6/25	510	1	DW	Grab	1			
404B	6/6/25	511	1	DW	Grab	1			
412A	6/6/25	512	1	DW	Grab	1			
412B	6/6/25	513	1	DW	Grab	1			
410A	6/6/25	514	1	DW	Grab	1			

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous

Relinquished By (signature) *Antony P. Stager*

Date/Time **6/6/25-1150**

Received By (signature) *Antony P. Stager*

Date/Time **6/6/25-1150**

Comments:

Drinking water samples
lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time


*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A



3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14843**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN **SAY**

Holding Time:

Samples Received on Ice? Yes No **N/A**

Custody Seals Intact? Yes No **N/A**

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Location: **BIG FLATS ELEM.**

PO No.: **25-02362**

Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Sampler Signature: **A. Stager**

Sampler Telephone No.:

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO₃(1), H₂SO₄(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	Sample Disposition	Requested Analysis	Addit
	410B	6/6/25	515	1	DW	Grab	1	LEAD IN DRINKING WATER		
	BOT GYM	6/6/25	517	1	DW	Grab	1			
	FGYM 1	6/6/25	518	1	DW	Grab	1			
	FGYM 2	6/6/25	519	1	DW	Grab	1			
	401A	6/6/25	521	1	DW	Grab	1			
	401B	6/6/25	522	1	DW	Grab	1			

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature) **Anthony P. Stager**

Date/Time **6/6/25 1150**

Received By (signature) **J. Palanza**

Date/Time **6/6/2025 150**

Comments:

Drinking water samples
lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time


*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No **N/A**



3821 Buck Dr.
Cortland, NY 13045
607.763.3403 (CRT)

4359 Lingletown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: ☐ Mail ☒ Fax ☒ E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreation Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: **CRT** HBG PTN **SAY**
Holding Time:

Samples Received on Ice? Yes No **N/A**

Custody Seals Intact? Yes No **N/A**

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

PO No.: **25-02362** Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Sampler Signature: *Antony P. Stager*

Location: **BIG FLATS ELEM.**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreation Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreation Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	REQUESTED ANALYSIS	Addit
	ART A	6/6/25	530	1	DW	Grab	1	LEAD IN DRINKING WATER	
	ART B	6/6/25	531	1	DW	Grab	1		
	ART C	6/6/25	532	1	DW	Grab	1		
	203A	6/6/25	533	1	DW	Grab	1		
	203B	6/6/25	534	1	DW	Grab	1		
	205A	6/6/25	535	1	DW	Grab	1		

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature) *Antony P. Stager*

Date/Time: **6/6/25 150**

Received By (signature) *Joseph Palanza*

Date/Time: **6/6/25 150**

Date/Time: **6/6/25 150**

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:


Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: **CRT** PTN

Samples Received on Ice? Yes No **N/A**

Same as Above ☐



3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Lingiestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoes.org**

Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN **(SAY)**

Holding Time:

Samples Received on Ice? Yes No **(N/A)**

Custody Seals Intact? Yes No **(N/A)**

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Solid/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Sampler Signature: *Antony P. Stager*

Sampler Telephone No.:

PO No.: **25-02362** Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Compliance Monitoring?

Yes ☐ No ☒

Agency/Program: **NYS DOH**

Sampler Telephone No.:

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	REQUESTED ANALYSIS	Additio
	206B	6/6/25	542	1	DW	Grab	1	LEAD IN DRINKING WATER	
	209A	6/6/25	543	1	DW	Grab	1		
	209B	6/6/25	544	1	DW	Grab	1		
	208A	6/6/25	545	1	DW	Grab	1		
	208B	6/6/25	546	1	DW	Grab	1		
	211A	6/6/25	547	1	DW	Grab	1		

Possible Hazard Identification

☐ Hazardous ☐ Non-Hazardous

☐ Radioactive

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature): *Antony P. Stager*

Date/Time: **6/6/25 11:50**

Received By (signature): *Joseph Palanza*

Date/Time: **6/6/2025 11:50**

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No **N/A**

Same as Above ☐

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN SAY

Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Compliance Monitoring? ☒ Yes ☐ No

If Yes: Agency/Program: NYS DOH

Sampler Telephone No.:

2310 Elmira St.

Sayre, PA 18840

570.888.0169 (SAY)

428 Route 315 Hwy

Pittston, PA 18640

570.348.0775 (PTN)

4359 Linglestown Rd.

Harrisburg, PA 17112

570.348.0775 (HBG)

3821 Buck Dr.

Cortland, NY 13045

607.783.3403 (CRT)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Location: BIG FLATS ELEM.

Sampler Signature: A. Stager

Sampled by (PRINT): ANTONY P. STAGER

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Solid/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

No. of Containers

REQUESTED ANALYSIS

Add

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	LEAD IN DRINKING WATER	Additional
211B		6/6/25	548	1	DW	Grab	1	X	
210A		6/6/25	549	1	DW	Grab	1	X	
210B		6/6/25	550	1	DW	Grab	1	X	
BOT 2		6/6/25	551	1	DW	Grab	1	X	
FNT 2		6/6/25	552	1	DW	Grab	1	X	
BOTCAFE		6/6/25	553	1	DW	Grab	1	X	

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature) *Anthony P. Stager*

Relinquished By (signature) *Joseph Palanza*

Date/Time 6/6/25 150

Date/Time 6/6/25 150

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:


Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

Page 10 of 14



3821 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Lingiestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Sayre, PA 18840
570.348.0775 (PTN)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoce.org**

Send Report via: ☐ Mail ☒ Fax ☒ E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO₃(1), H₂SO₄(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT HBG PTN

Holding Time:

Samples Received on Ice? Yes No

Custody Seals Intact? Yes No

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Compliance Monitoring? ☒ Yes ☐ No

If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Sampler Signature: *Antony P. Stager*

Location: **BIG FLATS ELEM.**

PO No.: **25-02362**



S 5 F 0 2 7 7

Horseheads Central School District
PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	REQUESTED ANALYSIS	Addl
	FNT CAFE 1	6/6/25	554	1	DW	Grab	1	LEAD IN DRINKING WATER	
	FNT CAFE 2	6/6/25	555	1	DW	Grab	1		
	MAIL F	6/6/25	557	1	DW	Grab	1		
	CON F	6/6/25	558	1	DW	Grab	1		
	BOT 1	6/6/25	559	1	DW	Grab	1		
	FNT 1	6/6/25	600	1	DW	Grab	1		
Possible Hazard Identification		☐ Hazardous ☐ Non-Hazardous		☐ Radiactive		Sample Disposition		☒ Dispose as appropriate ☐ Return ☐ Archive	

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature): *Antony P. Stager*

Relinquished By (signature): *Antony P. Stager*

Relinquished By (signature)

Date/Time: **6/6/25 1150**

Received By (signature): *Joseph Palanza*

Date/Time: **6/6/2025**

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):


Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Same as Above ☐



3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoes.org**

Send Report via: ☐ Mail ☒ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature:

Location: **BIG FLATS ELEM.**

PO No.: **25-02362**

Compliance Monitoring? ☒ Yes ☐ No

If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Solid/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)

** Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)



S 5 F 0 2 7 7

Horseheads Central School District

PM: Joseph Palanza

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	REQUESTED ANALYSIS	Addl
	NUR 1	6/6/25	602	1	DW	Grab	1	LEAD IN DRINKING WATER	
	NUR 2	6/6/25	603	1	DW	Grab	1		
	101A	6/6/25	604	1	DW	Grab	1		
	101B	6/6/25	605	1	DW	Grab	1		
	100A	6/6/25	606	1	DW	Grab	1		
	100B	6/6/25	607	1	DW	Grab	1		

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature) **Antony P. Stager**

Date/Time **6/6/25 1150**

Received By (signature) **J. Palanza**

Date/Time **6/6/25 1150**

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Date/Time

Date/Time

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Same as Above ☐

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY INITIAL RECEIVING MICROBAC:

Turnaround Time

☒ Routine (7-10 bus. days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C):
Thermometer ID:

Receiving Lab: CRT HBG PTN SAY
Holding Time:
Samples Received on Ice? Yes No N/A
Custody Seals intact? Yes No N/A

Report Type

☒ Results Only

☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4

☐ EDD

Compliance Monitoring? ☒ Yes ☐ No
If Yes: Agency/Program: **NYS DOH**

Sampler Telephone No.:

Sampler Signature: **A. Stager**
Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
Preservative Types: HNO3(1), H2SO4(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Location:

BIG FLATS ELEM.

PO No.: **25-02362**

Invoice Address

Client Name:

Address:

← SAME

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Report Email: **astager@gstboxes.org**

Send Report via: ☐ Mail ☐ Fax ☒ E-mail

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Project: **2025 COMPLIANCE**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature:

A. Stager

Sampler Telephone No.:

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	LEAD IN DRINKING WATER	Requested Analysis	Addl.
	103A	6/6/25	609	1	DW	Grab	1	X		
	103B	6/6/25	610	1	DW	Grab	1	X		
	102A	6/6/25	611	1	DW	Grab	1	X		
	102B	6/6/25	612	1	DW	Grab	1	X		
	105A	6/6/25	613	1	DW	Grab	1	X		
	105B	6/6/25	614	1	DW	Grab	1	X		

Possible Hazard Identification

☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature)

Antony P. Stager

Date/Time

6/6/25 1150

Received By (signature)

J. Palanza

Date/Time

6/6/2025 1150

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Same as Above ☐


Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.

Page 13 of 14



3921 Buck Dr.
Cortland, NY 13045
607.753.3403 (CRT)

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700 (HBG)

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775 (PTN)

2310 Elmira St.
Sayre, PA 18840
570.888.0169 (SAY)

CHAIN OF CUSTODY RECORD

Number
Instructions on back

Lab Report Address

Client Name: **HORSEHEADS CSD**

Address: **507 FLETCHER ST**

City, State, Zip: **HORSEHEADS NY 14845**

Contact: **TONY STAGER**

Telephone No.: **607-795-2592**

Report Email: **astager@gsthoes.org**

Send Report via: ☐ Mail ☒ Fax ☒ E-mail

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Invoice Email:

Send Invoice via: ☐ Mail ☐ Fax ☒ E-mail

Location:

BIG FLATS ELEM.

PO No.:

25-02362

Compliance Monitoring? ☒ Yes ☐ No

If Yes: Agency/Program: **NYS DOH**

Sampled by (PRINT): **ANTONY P. STAGER**

Sampler Signature:

Antony P. Stager

Sampler Telephone No.:

* Matrix Types: Drinking Water (DW), Groundwater (GW), Surface/Storm Water (SW), Wastewater (WW), Recreational Water (RC), Soil/Solid (S), Sludge (SL), Oil (O), Wipe (W), Other (specify)
** Preservative Types: HNO₃(1), H₂SO₄(2), HCl(3), NaOH(4), Sodium Thiosulfate(5), Ammonium Chloride(6), Ammonium Sulfate(7), EDA(8), Hexane(9), Methanol(10), Sodium Bisulfate(11), Sodium Sulfite(12), Zinc Acetate(13), Unpreserved (U), Other (specify)

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix *	Grab / Composite	Preservative **	REQUESTED ANALYSIS	Addit
10419		6/6/25	6:15	1	DW	Grab	1	LEAD IN DRINKING WATER	
10418		6/6/25	6:16	1	DW	Grab	1		
BOT 4		6/6/25	6:20	1	DW	Grab	1		
FNT 4		6/6/25	6:21	1	DW	Grab	1		
FNT 5		6/6/25	6:22	1	DW	Grab	1		
		6/6/25		1	DW	Grab	1		

Possible Hazard Identification ☐ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Comments:

Drinking water samples
Lead in DW analysis
Not preserved - to
be preserved @ lab

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

*** TO BE COMPLETED BY FINAL RECEIVING MICROBAC:

Temperature Upon Receipt (°C):

Same as Above []

Thermometer ID:

Receiving Lab: CRT PTN

Samples Received on Ice? Yes No N/A

*** If Initial and Final Receiving Microbac are the same, check "Same as Above" in Final Receiving Box.



S 5 F 0 2 7 7

Horseheads Central School District

PM: Joseph Palanza