

## Center Street Elementary School - Water Testing Summer 2021

Sample Identification	Description	Initial Results
KIT1	Kitchen	245
KIT2	Kitchen	15.6
KIT3	Kitchen	12.1
KIT4	Kitchen	21.5
BOT-1	Bottle Filler, Cafeteria	<1.0
104F	Classroom	8.0
107F	Classroom	7.6
102F	Classroom	3.5
105F	Classroom	11.3
STFLAV-1	Staff Lav by 103	4.1
103F	Classroom	8.7
NUR1	Nurses Office	3.3
NURL	Nurses Office Lav	5.7
101F	classroom	5.6
PE-1	PE Office	9.3
FAC-1	Fac Lav across from 113	3.7
115F	Classroom	5.8
110F	Classroom	5.1
113F	Classroom	3.9
112F	Classroom	2.3
117F	Classroom	4.3
114F	Classroom	14.0
FAC-2	Fac Lav by 114	<1.0
BOT-2	Bottle Filler across from 116	<1.0
121F	Classroom	5.8
118F	Classroom	5.3
123F	Classroom	3.2
120F	Classroom	4.7
125F	Classroom	7.1
122F	Classroom	6.9
LIBF	Library	20.3
201F	Classroom	10.2
200F	Classroom	2.3
203F	Classroom	2.1
202F	Classroom	3.5
205F	Classroom	6.4
207F	Classroom	6.4
204F	Classroom	8.8
206F	Classroom	8.5
209A	Classroom	4.1
209B	Classroom	3.6
209C	Classroom	5.5
208F	Classroom	11.6
SS-1	Faculty Lav by Student Services Office	<1.0

NYSDOH Action Level for Lead of 15 ppb