

Ridge Road Elementary School - Water Testing Summer 2021

Sample Identification	Description	Initial Results	Results After Remediation
KIT 1	Kitchen - Draw 1	11.1	3.0
KIT 1A	Kitchen - Draw 2	4.4	
KIT 2	Kitchen - Draw 1	4.4	
KIT 2A	Kitchen - Draw 2	<1.0	
KIT 3	Kitchen - Draw 1	9.4	
KIT 3A	Kitchen - Draw 2	<1.0	
KIT 4	Kitchen - Draw 1	5.7	
KIT 4A	Kitchen - Draw 2	<1.0	
KIT 5	Kitchen - Draw 1	19.8	
KIT 5A	Kitchen - Draw 2	1.2	
136	Classroom - Draw 1	5.2	
136A	Classroom - Draw 2	<1.0	
133	Classroom - Draw 1	4.7	
133A	Classroom - Draw 2	<1.0	
131	Classroom - Draw 1	5.9	
131A	Classroom - Draw 2	<1.0	
134	Classroom - Draw 1	3.0	
134A	Classroom - Draw 2	<1.0	
132	Classroom - Draw 1	7.1	
132A	Classroom - Draw 2	<1.0	
130	Classroom - Draw 1	4.7	
130A	Classroom - Draw 2	1.8	
129	Classroom - Draw 1	4.0	
129A	Classroom - Draw 2	<1.0	
M1F1	Men's Lav by Rm 130 Draw 1	7.4	
M1F1A	Men's Lav by Rm 130 Draw 2	3.6	
W1F1	Women's Lav by Rm 130 Draw 1	9.8	
W1F1A	Women's Lav by Rm 130 Draw 2	<1.0	
128	Classroom - Draw 1	4.0	
128A	Classroom - Draw 2	<1.0	
127	Classroom - Draw 1	4.7	
127A	Classroom - Draw 2	<1.0	
126	Classroom - Draw 1	5.8	
126A	Classroom - Draw 2	<1.0	
124	Classroom - Draw 1	7.5	
124A	Classroom - Draw 2	<1.0	
122	Classroom - Draw 1	4.1	
122A	Classroom - Draw 2	<1.0	
114	Classroom - Draw 1	1.7	
114A	Classroom - Draw 2	<1.0	
115	Classroom - Draw 1	6.6	
115A	Classroom - Draw 2	<1.0	
116	Classroom - Draw 1	<1.0	

116A	Classroom - Draw 2	<1.0	
117	Classroom - Draw 1	<1.0	
117A	Classroom - Draw 2	<1.0	
118A	Classroom - Draw 1	2.5	
118A1	Classroom - Draw 2	12.6	
118B	Classroom - Draw 1	3.2	
118B1	Classroom - Draw 2	2.7	
118C	Classroom - Draw 1	9.0	
118C-1	Classroom - Draw 2	2.9	
119	Classroom - Draw 1	<1.0	
119A	Classroom - Draw 2	<1.0	
121	Classroom - Draw 1	2.5	
121A	Classroom - Draw 2	<1.0	
MOC	Main Office Conf Rm - Draw 1	1.6	
MOCA	Main Office Conf Rm - Draw 2	<1.0	
103	Classroom - Draw 1	10.3	
103A	Classroom - Draw 2	1.1	
104	Classroom - Draw 1	<1.0	
104A	Classroom - Draw 2	<1.0	
105	Classroom - Draw 1	26.1	2.3
105A	Classroom - Draw 2	<1.0	
106	Classroom - Draw 1	18.4	1.9
106A	Classroom - Draw 2	1.4	
107	Classroom - Draw 1	2.5	
107A	Classroom - Draw 2	<1.0	
108	Classroom - Draw 1	6.8	
108A	Classroom - Draw 2	<1.0	
109	Classroom - Draw 1	7.7	
109A	Classroom - Draw 2	<1.0	
N1	Nurses Office - Draw 1	9.3	
NUR1A	Nurses Office - Draw 2	<1.0	
N2	Nurses Office Lav - Draw 1	7.6	
NUR2A	Nurses Office Lav - Draw 2	<1.0	
LIB	Library - Draw 1	34.5	3.0
LIBA	Library - Draw 2	4.9	
GYM1	Gym - Draw 1	13.5	
GYM1A	Gym - Draw 2	<1.0	
BOT1	Bottle Filler by Music Room - Draw 1	<1.0	
BOT1A	Bottle Filler by Music Room - Draw 2	<1.0	
BOT2	Bottle Filler by Gym - Draw 1	<1.0	
BOT2A	Bottle Filler by Gym - Draw 2	<1.0	
BOT3	Bottle Filler by Nurse's Office - Draw 1	<1.0	
BOT3A	Bottle Filler by Nurse's Office - Draw 2	<1.0	
TLR-1	Faculty Lounge by Nurse's Office - Draw 1	2.2	
TLR-1A	Faculty Lounge by Nurse's Office - Draw 2	<1.0	

TLR-2	Faculty Lounge by Nurse's Office Lav 1 - Draw 1	2.2	
TLR-2A	Faculty Lounge by Nurse's Office Lav 1 - Draw 2	<1.0	
TLR-3	Faculty Lounge by Nurse's Office Lav 2 - Draw 1	<1.0	
TLR-3A	Faculty Lounge by Nurse's Office Lav 2 - Draw 2	<1.0	

NYSDOH Action Level for Lead of 15 ppb